

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/School/WZ/2022/ 948

Dated: 5 / 9 /2022

FIRE SAFETY CERTIFICATE

Certified that the **Jesus Mary Joseph School** Located at **G-17, Site 10, Paschim Vihar, New Delhi-110063**, comprised of Ground + 03 Upper Floors was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/WZ2019/1545 dated 26.07.2019**. The said premise was re-inspected by the officer concerned of this department on 12.08.2022 in the presence of Sr. Divya Thomas (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with rule D.O.E. Circular No. 3298-3398 dated 01.03.2011/NBC (Part-IV) and that the premises/building is fit for occupancy class 'Educational Building' Group B with effect from _____ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on _____ at New Delhi by.



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi- 110054.
2. The Principal, Jesus Mary Joseph School, G-17, Site 10, Paschim Vihar, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form J (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.


29/8/22

INSPECTION REPORT

H-16

1. Name & address of the building: **Jesus Mary Joseph School** Located at **G-17, Site 10, Paschim Vihar, New Delhi-110063.**
2. Type of Occupancy : Educational,
3. Type of Case : Renewal (Ground + 03 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/School/WZ/2019/1545 dated 26.07.2019
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/357 dated 29.11.2013
6. Date of inspection : 12.08.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sr. Divya Thomas (Principal)
9. Year of Construction : 2009-10 & 2015-16
10. Applicant's letter No. : 024 dated 14.07.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr. No. 3298-3398 dated 01.03.2011/NBC Requirement/as per FSC dated 26.07.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	25 m	MR
	• Gate width	05 m	05 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.5 m x 5 (Up to 2 nd floor), 1.5 m x 4 (Up to 3 rd floor)	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	•	04	04	MR
	e. Width Of Corridor			
	f. Door Size	1.5 m	Provided	MR
		01 mts. (Class Room)	A) 1 mts. each class rooms	MR
		1.5 mts. (Hall)	B) 2 m x 2 & 1.5 m x 1 in hall	
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

MIR
MIR
R

H-18

19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2019/1545 dated 26.07.2019 is recommended under rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Q11TH
16/08/22
Aman Kumar Lathar
ADO (JWP)

~~DO (W)~~

D.O (WEST) ~~16/8/2022~~
DATED: 16/8/2022

~~DFS (W2)~~
[Signature]
16/8/22

~~ADO (W2)~~
F.i. letter is put-up for signature M.

~~ADO (W2)~~

[Signature]
31/8/22

Q11TH
20/8/22
ADO (W2)

NS/uy