

C14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001


No F 6/DFS/MS/2022/School/WZ/ 957

Dated: 5 / 9 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **North M. C. D. Primary Co-ed School, Sector-26, Rohini, Delhi-85**, comprised of **Ground + 01 upper floor** owned/occupied by **North M. C. D. Primary Co-ed School** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/2018/WZ/1033** dated **11.05.2018**. The premises was re-inspected by the officer concerned of this department on **08.08.2022** in the presence of **Mr. Ravinder Singh (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no 3298-3398** dated **01.03.2011** and the building/ premise is fit for occupancy **Group B Educational** with effect from **09/9/22** for a period of **three years**, subject to compliance of the conditions mentioned below.

Issued on **09/9/22** at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to: -

1. The Deputy Commissioner, Narela Zone, North Delhi Municipal Corporation, Opp. Police Station, Narela, Delhi, 110040.
2. The Principal, North M. C. D. Primary Co-ed School, Sector-26, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

N110

INSPECTION REPORT

1. Name & address of the building : North M. C. D. Primary Co-ed School, Sector-26, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 01 floor**)
4. Details of Previous NOC : F.6/DFS/MS/School/2018/WZ/1033 dated 11.05.2018.
5. Fire Safety directives letter No : Director of Education Cir dated 01.03.2011.
6. Date of inspection : 08.08.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Ravinder Singh (Principal)
9. Year of Construction : 2000
10. Applicant's letter No. : Online e-mail dated 29.07.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Cir dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible 4.5m NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 08nos. ABC/CO2 ISI marked 	<ul style="list-style-type: none"> 10nos. ABC-10 Yes 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA

