



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI

(-3)

No. F6/DFS/MS/School/WZ/2022 / 955

Dated: 17/8/22

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya, No. 02, (ID-1515023) (Old Building)** located at **Punjabi Bagh, New Delhi-110026**, comprised of **Six Blocks (04 BL= Ground + One Upper Floor & 02 BL= Ground Floor only)** was issued FSC vide Letter No. F6/DFS/MS/WZ/2019/1053 dated 17/05/2019. The premises was re-inspected by officer concerned of this department on 16/08/2022 in the presence of Smt. Kusum Lata (HOS) and observed that all the fire prevention and fire safety arrangements provide in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular dated 01/03/2011/NBC (Part-IV) and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from17/8/22..... for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 conditions mentioned below.

Issued on17/8/22..... at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to:

1. The HOS, M/s. Sarvodaya Kanya Vidyalaya, No. 02, (ID-1515023) (Old Building) located at Punjabi Bagh, New Delhi-110026.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Sarvodaya Kanya Vidyalaya, No- 2, Located at Punjabi Bagh, (School ID- 1515023) New Delhi – 110026.**
2. Type of Occupancy : **Educational Six Block (04 BL = G + 01 upper floor & 02 BL = Ground floor only)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F.6/DFS/MS/WZ/2019/1053 dated 17/05/2019**
5. Fire Safety directives letter No : **DOE 3298-3398 dated 01/03/2011**
6. Date of inspection : **16/08/2022**
7. Name of the Inspecting Officers : **Sh. Sarabjeet Singh ADO (MN)**
8. Name and designation of officers from the building side : **Smt. Kusum Lata (HOS)**
9. Year of Construction :
10. Applicant's letter No. : **Email dated 29/07/2022**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011 As per prev. insp. dated 16/08/2022	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01 in each block	05 Provided	MR (old case)
	• Upper Floors			
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m each	BL-1= 2x150cm. BL-2= 150cm. BL-3 = 175cm BL-4= 155cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	175 cm Provided	MR
	g. Door Size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	17 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

24

M-14

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

H

S

10

Provision of Lifts.			
16	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
17	Standby power supply	NA	NA
18	Refuge Area.		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2019/1053 dated 17/05/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (WZ)~~

~~Signature of the Inspecting Officer~~

Name: Sarabjeet Singh
Designation: ADO (MN)

271/ADO/MN
22/8/22

~~Signature~~
22/8/2022

~~DCP (WZ)~~

~~Signature~~

D.O. WESTY 634
DATED 22/08/22

Sir, F. T is put up for your kind personal & signature please.

Signature
25/8/22