

4107

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2022/ 403

Dated : 01/09/2022

FIRE SAFETY CERTIFICATE

Certified that the **Pink City Guest House** located at **4252, Gali Krishna, Pahar Ganj, New Delhi** comprises of **Ground + Mezzanine + 02 Upper floor, Ground floor (Reception + 02 guest rooms), Mezzanine floor (owner Residence), 1st & 2nd floor (05 guest rooms at each floor), total 12 guest rooms** was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/2019/2000 dated 18/10/2019 in the name & style Pink city guest house . Now, the premises was re-inspected by the officer concerned of this department on 24/08/2022 in the presence of **Manager** and found that the said guest house building having ground, mezzanine and two upper floor, has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **(Residential Group A-1) Ground floor (Reception + 02 guest rooms), 1st & 2nd floor (05 guest rooms at each floor), total 12 guest rooms up to second floor**, with effect from 01/09/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/09/2022 at New Delhi by.


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Center, New Delhi. : to ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online id no.2022052411090 dated 03.06.2022.
3. The Manager,
Pink City Guest House, 4252, Gali Krishna, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/40

INSPECTION REPORT

1. Name & address of the building : Pink City Guest House located at 4252, Gali Krishna, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
Gr + Mezzanine +02 Upper floors (total 12 Guest rooms)
Ground floor (Reception +02 guest rooms)
1st & 2nd floor (05 guest rooms), mezzanine – residence
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/GH/2019/2000 dated 18/10/2019
5. Fire safety directives No.- N/A
6. Date of inspection:- 24/08/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Manager
9. Year of construction:- 1982
10. Applicant's letter No:- 2022052411090 dated 03.06.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	N/A	MR
	2) Gate width	N/A	02 mtr.	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	0.96 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.25 mtr.	1.5 mtr.	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	NA	N/A	N/A
	2) Upper floors	12 ACPH	Natural Ventilation/exhaust	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

21/21

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	01	N/A
	2) Length of hose reel hose	N/A	30 mtr.	N/A
	3) Nozzle diameter	N/A	05 mm	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Each floor	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	450 LPM	N/A
	b) Head of pump	N/A	30 mtr.	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR

		Required	Provided	MR
15	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no F6/DFS/MS/GH/2019/2000 dated 18/10/2019. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name :- Ravinder Singh
Designation :- ADO (CC)

Handwritten: 29/8/22

Handwritten: Dy. Insp. W.P.

Handwritten: F.T. please.

Handwritten: 31/08/22

Handwritten: ADO (CC)

Handwritten: As approved, reply put up for ICW perusal and signature please

Handwritten: Dy. Insp. W.P.

Handwritten: F.P. wing

Handwritten: 01/09/22

Handwritten: 01/09/22