



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/2
आजुर्वादिना
अमृत महोत्सव


No. F6/DFS/MS/School/WZ/2022/ 952

Dated: 5/9/22

FIRE SAFETY CERTIFICATE

Certified that the **Prabhu Dayal Public School** located at **Dakshini Block-A, Shalimar Bagh, Delhi- 110034**, comprised of Ground plus two Upper Floor was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2019/643 dated 27.03.2019. The school building was re-inspected by the officer concerned of this department on 29.08.2022 in the presence of Sh. Bahadur Singh (IT Admin) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 5/9/22 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on ..5/9/22..... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Prabhu Dayal Public School located at Dakshini Block-A, Shalimar Bagh, Delhi- 110034.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Prabhu Dayal Public School, Dakshini Block-A, Shalimar Bagh, Delhi- 110088.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/2019/643 dated 27.03.2019
5. Fire Safety directives letter No : D.o.E Circular 262-362 dated 17.01.2005
6. Date of inspection : 29.08.2022
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO (West)
8. Name and designation of officers from the building side : Sh. Bahadur Singh (I.T. Admin)
9. Year of Construction : 1984
10. Applicant's letter No. : PDPS/FS/2022/669 dated 01.08.2022

The school building is comprised of ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6) of DFS Act/DoE Cir. dt. 17.01.2005	Provided at site	Remarks MR/NMR									
1	Access to building												
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>Accessible</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>Accessible</td> <td>3.80</td> <td>MR being old case</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table>	Accessible	Provided	MR	Accessible	3.80	MR being old case	N/A	N/A	N/A		
Accessible	Provided	MR											
Accessible	3.80	MR being old case											
N/A	N/A	N/A											
2	Number, Width, Type & Arrangement of Exits												
	a. Number of staircases	-----	-----	-----									
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03	05	MR									
	b. Width of staircases	N/A	N/A	N/A									
	<ul style="list-style-type: none"> • Upper Floors • Basements 	-----	-----	-----									
	1.5 mts	GF - Terrace = 03 x 1.10 mts, GF - FF = 1.8 & 1.7 mts		MR									
	c. Protection of exits	N/A	N/A	N/A									
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-----	-----	-----									
	N/A	N/A	N/A	N/A									
	e. No. of continuous staircases to terrace	N/A	N/A	N/A									
	g. Width of Corridor	03	03	MR									
	h. Door Size	N/A	N/A	N/A									
	N/A	N/A	N/A	N/A									
3	Compartmentation.												
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
4	Smoke Management System.												
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A									
		12 a/c per hour	Natural ventilation	MR									
5	Fire Extinguishers												
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 nos. ABC, CO ₂ type ISI marked	Provided	MR									
			Provided	MR									
			Provided	MR									


	Standby power supply	N/A	N/A	N/A
	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - All the shortcomings pointed out by this department vide this office letters dated 26.07.2022, 10.06.2022 & 13.05.2022 have been complied with by the school management.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the renewal of the NOC issued vide letter No. F.6/DFS/MS/WZ/2019/643 dated 27.03.2019, is recommended.

DFA is put up for approval & signature please.


28/8/2022

Signature of the Inspecting Officer
Divisional Officer (West Division)

DO (West) 470
DATED: 29/8/2022


~~DOFO (WZ)~~


11/9/2022

~~DO/West~~

F.T. letter is put up for Signa please.

~~DOFO (WZ)~~


15/9/2022



MS/CCJ