



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/School/WZ/2022 / 959

Dated: 5/9 /2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Vidyalaya (Sarvodaya Co. Edu. Senior Secondary School)** Located at **East Punjabi Bagh New Delhi-110026, (School ID-1515004)**, comprised of 02 Blocks (Ground + 01 Upper Floor), was issued FSC vide letter No. F6/DFS/MS/School/WZ/2019/1348 dated 27/06/2019. The premises was inspected by the officer concerned by this department on 16/08/2022 in the presence of Sh. Avinash (Teacher) and found that the said school building deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education Govt of NCT of Delhi, and that the building/premises is fit for the occupancy class "Educational" Group B with effect from 27/9/22.... for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 conditions mentioned below:-

Issued on 27/9/22.... at New Delhi.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

**Copy to:**

1. The Principal, Sarvodaya Vidyalaya (Sarvodaya Co. Edu. Senior Secondary School) (ID-1515004) located at East Punjabi Bagh, New Delhi-110026.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. **The upper floor in Block- 2, having one staircase strictly shall not be used for school activity.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1. Name & address of the building: Sarvodaya Vidyalaya (Sarvodaya Co. Edu. Senior Secondary School) Located at East Punjabi Bagh, New Delhi – 110026. **(School ID – 1515004)**
2. Type of Occupancy : Educational 02 Block (Ground + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/WZ/2019/1348 dated 27/06/2019
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 16/08/2022
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer from the building side : Sh. Avinash (Teacher)
9. Year of Construction : 2017 (As per prev. insp. report dated 17/06/2019)
10. Applicant's letter No. : Letter No.SV/EPB/664 dated 01/08/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Old BL-2 = 155cm Old BL-1 = 156cm & 155cm	MR (old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2 x 1 m	Provided	MR (old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

2

6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fire man's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

NA  
NA  
NA



17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

**Note:** - As undertaking given by the school authority the upper floor of Block- 2 having only one staircase of 1.53 m strictly shall not be used for school activity.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F6/DFS/MS/School/WZ/2019/1348 dated 27/06/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Do (just)~~

~~Signature~~  
~~22/8/2022~~

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

245/ADO/MN  
22/8/2022  
D.O (WEST) 653  
DATED. 22/8/2022

~~Defo (w2)~~  
~~22/8~~  
~~28/8/2022~~

~~ADP M.N~~ Sir, F. T is put up for your kind  
personal & signature please.

~~Signature~~  
~~25/8/2022~~

~~Defo (w2)~~  
~~28/8/2022~~  
WST all