

47

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/ 240

Dated: 30/8/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s UBER Lounge** located at **M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048** in the building comprised of Basement, ground plus three upper floor owner occupied by **Silver Spoon Entertainment Pvt Ltd.**, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 26/08/2022 in the presence of Mr. Rakesh Tiwari and that the premises is fit for (**Restaurant at Ground floor only**) occupancy class "**Group-D Assembly Building**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/8/2022 at New Delhi by


(ATUL GARG)
DIRECTOR

etc

Copy to: -

1. The Dy. Health Officer, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi – 110016. (Ref. MHA Portal ID 2022082516575 dated 25/08/2022)
2. M/s UBER Lounge located at M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

P/16

INSPECTION REPORT

1	Name & Address of the Building	M/s UBER Lounge (A unit of Ms Silver Spoon entertainment Pvt Ltd) M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048		
2	Type of Occupancy	Group- D Assembly Building		
3	Building Comprised of	Basement (Storage & Officer).Ground Floor (Restaurant) 1 st to 3 rd floor Upper floor (other property)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	UBBL-2016 / NBC Part-IV		
7	Date of Inspection	26/08/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Vishnu		
10	Year of construction	1982 Rest. at GF only		
11	Applicant letter No	MHA Portal ID 2022082516575 dated 25/08/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required	9m	MR
		N/A	Assessable from road	N/A
		N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Restaurant at ground floor only		
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 mtr x 2	1.60 & 1.50 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	N/A	N/A
		12 ACPH	N/A	N/A
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	06 Nos	06 Nos	MR
		ABC/CO ₂	ABC & CO ₂	MR
		ISI marked	Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A

2/17



	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	NA	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. 	N/A	N/A	N/A
		N/A	N/A	N/A

	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 519 dated 08/08/2022.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please

26/08/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

Dy. CFO (SZ)

[Signature]
29/8

CFO
[Signature]
30/8/2022

Director *[Signature]*
30/8/22

FT P 5
F.I. letter is put up for
inspecting officer's
signature
please

DIR/SZ
[Signature]
30/8/22

Director *[Signature]*
30/8/22

[Signature]

uploaded
30/8/22
[Signature]