

C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022 / 979

Dated: 7 / 9 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **M.C .Primary School** located at **Indra Nagar, Adarsh Nagar, Delhi-110033** comprised of **Ground + 01 upper floor** owned/occupied by **M.C. Primary Boys School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/School/20119/WZ/299** dated **06.02.2019**. The premises was re-inspected by the officer concerned of this department on **30.08.2022** in presence of **Sh. Satpal Singh (Librarian)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ...7 / 9 / 22... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...7 / 9 / 22... at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250
ofc op

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, M.C .Primary School located at Indra Nagar, Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/12

INSPECTION REPORT

1	Name & address of the building	M C Primary School, Indra Nagar, Adarsh Nagar, Delhi-110033
2	Type of Occupancy	Educational
3	Composition of building	Ground & First floor only
4	Type of Case	Renewal
5	Details of previous NOC	16 DIS MS School 2019 W/ 299 dated 06 02 2019
6	Fire Safety directives letter No	Director of Education Circular dated 01 03 2011
7	Date of inspection	30 08 2022
8	Name of the Inspecting Officers	ADO (RN)
9	Name and designation of officers from the building side	Sh Satpal Singh (Librarian)
10	Year of Construction	2007-2008
11	Applicant's letter No	Nil Dated 10 10 2018

Plot Area-800 m2		Covered Area 650 m2		No of Class Room-13nos		No of Student-241nos	
Minimum Standards on fire prevention and fire safety U/R 33		Circular of Director of Education		Provided at site		Remarks MR/NMR	
1	Access to building						
	• Road width		6m		6m		MR
	• Gate width		4.5m		4.5m		MR
	• Width of internal road		NA		NA		NA
2	Number, Width, Type & Arrangement of Exits						
	a. Number of staircases						
	• Upper Floors		01		02		MR
	• Basements		NA		NA		NA
	b. Width of staircases						
	• Upper Floors		1.5 m		1.65m & 1.40m		MR
	• Basements		NA		NA		NA
	c. Protection of exits						
	• Fire check door		NA		NA		NA
	• Pressurization		NA		NA		NA
	d. No of continuous staircases to terrace		NA		NA		NA
	e. Width of Corridor		NA		NA		NA
	f. Door Size		1 m		1.10m double door		MR
3	Compartmentation.						
	• Fire check door		NA		NA		NA
	• Sealing of electrical shafts		NA		NA		NA
	• Fire Rating of shaft door		NA		NA		NA
	• Water Curtain		NA		NA		NA
	• Fire Dampers		NA		NA		NA
4	Smoke Management System.						
	• Basements		12 a/c per hour		NA		NA
	• Upper floors		12 a/c per hour		Natural Ventilated		MR
5	Fire Extinguishers						
	• Total numbers		05nos		07nos		MR

By

Cont- PTO

N/13

	ABC Co2	ABC 07	MR
	ISI Marked	Yes	MR
6	First-Aid Hose Reels.		
	• Types		MR
	• ISI marking	Yes	MR
	• Total numbers on each floor	NA	NA
	• Length of hose reel hose	NA	NA
	• Nozzle diameter	NA	NA
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	NA	NA
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	NA	NA
	➤ Head of Main pump	NA	NA
	➤ Number of main pumps	NA	NA
	➤ Jockey Pump out put	NA	NA
	➤ Jockey pump head	NA	NA
	➤ Standby Pump out put	NA	NA
	➤ Standby Pump Head	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA
	➤ Pump House Access	NA	NA
	• Terrace level	NA	NA
	➤ Discharge of pump	NA	NA
	➤ Head of the pump	NA	NA
	➤ Power Supply	NA	NA
	➤ Auto Starting of pump	NA	NA
14	Captive Water Storage for fire fighting.		

Go

N/14

MR	• Underground tank capacity	NA	NA	NA
M'	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			NA
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.299 dated 06.02.2019.

~~DO (M)~~

~~31/08/2022~~

~~31/8/2022~~

~~ADO R-N~~

As approved, F.T. letter is put up for your signature pl

Signature of the Inspecting Officer
 Name: C.I. Meena
 Designation - ADO RN

~~05/08/2022~~

Cont... PTO