

C-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/School/2022 / 977

Dated: 7 / 9 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C Primary School** located at **First floor Roshnara Road (Co-ed) Delhi-110007** in the building comprised of ground & first floor only owned/occupied by **M.C Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/School/2018/WZ/438** dated **16.03.2018**. The premises was re-inspected by the officer concerned of this department on **30.08.2022** in presence of **Sh. Shiv Kumar (Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **"Group B Educational"** for first floor only with effect from .....**7/9/22**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on .....**7/9/22**..... at New Delhi by

  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250  
dc qp

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Incharge, M.C Primary School located at First floor Roshnara Road (Co-ed) Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBI-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBI.-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form "J"** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	02nos ABC/Co2 ISI Marked	04nos ABC 04 Yes	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA NA NA	NA NA NA	NA NA NA
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level                     <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                     <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A

**Captive Water Storage for fire fighting.**

	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.438 dated 16.03.2018.

*DO (MW)*

*31/06/2022*

*31/06/2022*

*31/06/2022*

*AAO/R-N*

As approved, F.T. letter is setup for your signature pl.

Signature of the Inspecting Officer  
 Name - C.I. Meena  
 Designation - ADO/RN

*05/09/2022 P.T.O.*

N/9

**INSPECTION REPORT**

N/A

N/A

N/A

N//

1	Name & address of the building	M C Primary School at Roshanara Road (Co-cd). Delhi-110007
2	Type of Occupancy	Educational
3	Composition of building	Ground & first floor but school is running at first floor only
4	Type of Case	Renewal
5	Details of previous NOC	F6 D/S MS School 2018 W/ 138 dated 16.03.2018
6	Fire Safety directives letter No	Director of Education Circular dated 01.03.2011
7	Date of inspection	30.08.2022
8	Name of the Inspecting Officers	ADO (RN)
9	Name and designation of officers from the building side	Sh. Shiv Kumar (Incharge)
10	Year of Construction	1910
11	Applicant's letter No	Letter No Nil & D/S Dairy No 3915 Dtaed 29.07.2022

Covered Area 525m<sup>2</sup>

No. of Class Room-06

No. of Student 100

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6m 4.5m NA	5m 4.5m NA	MR(old case) MR NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	02	MR
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>			
	b. Width of staircases	1.5 m	1.30 m & 1m	MR(old case)
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1.2m double door	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	12 a.c per hour 12 a.c per hour	NA Natural Ventilated	NA MR
5	<b>Fire Extinguishers</b>			

Sp