

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2022/ 52/44/406

Dated: 05/9/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Hotel Marigold (A unit of RJS Banquets), Located at 1st, 2nd & 3rd Floors, Plot No.11, Sector-10, Dwarka, New Delhi in a building comprised of Basement + Ground + 03 Upper (1st Floor= 06 Rooms & 2nd & 3rd Floor =07 Rooms at each floor, Total=20 Rooms) Floors owned/ occupied By Hotel Marigold (A unit of RJS Banquets) have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 25/08/2022 in the presence of Sh Sanjeev Malhotra and found that the said building is fit for occupancy class "Residential" Group A-5 (Guest House at 1st 2nd & 3rd floors, Total Rooms=20) with effect from 05/09/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..05.09.22... at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Dy. Health Officer, Najafgarh Zone, SDMC Building, Dhansa Stand, Najafgarh, New Delhi-110054.
3. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.
4. The Hotel Marigold (A unit of RJS Banquets), Located at Plot No.11, Sector-10, Dwarka, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

276
INSPECTION REPORT

1. Name & address of the building: Hotel Marigold (A unit of ~~RSS~~ Banquets),
Located at Plot No.11, Sector-10, Dwarka, New Delhi.
2. Type of Occupancy : Lodging or rooming "A-1"
3. Type of Case : New (Basement + Ground + 3 Upper Floor)
4. Details of previous NOC : New
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 25/08/2022
7. Name of the Inspecting Officer : DO / SW & ADO (DWK)
8. Name and designation of Officer
from the building side: Sh. Sanjeev Malhotra
9. Year of Construction : 2009
10. Applicant's letter No. : 2022032304019 Email dated 21/07/2022

Basement – Storage
G. Floor= Bank
1st Floor-6 guest room
2nd Floor 7 guest rooms
3rd floor-7 guest rooms

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	NA	Direct Accessible From Road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR

276

N17

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 Nos. ABC & CO2 Required	Provided CO ₂ & ABC Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 mtr 5 MM	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	CO detector Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	Provided One provided Provided	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 900LPM 40 mtrs Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 15000 ltr	NA NA NA NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR

16.
17. Standby
18. Refur

ABC	MR
	MR
	MR
	MR
	MR
	MR
	MR
	MR
	MR
	MR

N/A

Provision of Lifts				
16.	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

[Signature]
26/8/22

Signature of the Inspecting Officer
Name *Sh Veal Pal*
Designation *DO/SO*

[Signature]
26/8/22

Signature of the Inspecting Officer
Name *Uday Vir Singh*
Designation *ADD/DWR*

[Signature]
26/8/22

[Signature]
26/8/22

[Signature]

[Signature]
29/8/2022

[Signature]
30/8/22

[Signature]
31/8/22
ADD (Member)