

L-78

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2022/ 998

Dated: 13.1.2022

**FIRE SAFETY CERTIFICATE**

Certified that the **M. C. Primary School** located at Ahata Kidara, Delhi – 06, is comprised of **Ground(Dispensary) + first floor (School) only**, was earlier granted FSC by this department vide letter No. **F6/DFS/MS/School2013/789** dated **22/02/2013**. Now, the premises was re-inspected by the officer concerned of this department on 06/09/22 in the presence of **Smt. Pooja (Principal)** and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398** dated **01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B “Educational Building” Sub-Div. B-I at ground floor** with effect from.....13.1.2022 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on .....13.1.2022 at New Delhi by.

S.K. Dua  
12/09/22

Dy. Chief Fire Officer  
Delhi Fire Service

L

Copy to:-

1. The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.
2. The Principal,  
M. C. Primary School Ahata Kidara, Delhi – 06.

**Condition for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
2. The owner / occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.

4/8

**INSPECTION REPORT**

1. Name & address of the building:- M. C. Primary School located at Ahata Kidara, Delhi - 06
2. Type of occupancy:- Educational Group B-I, Ground(Dispensary) + first floor (School) only,
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/School2013/789 dated 22/02/2013.
5. Fire safety directives No.- N/A
6. Date of inspection:- 06/09/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Smt. Pooja (Principal)
9. Year of construction:-
10. Applicant's letter No:- DFS diary no.3967 dated 01.08.2022.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	05 meter	05 mtr.	MR
	2) Gate width	NA	Directly accessible from road	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 meter	3.10 meter	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	1 mtr.	1 mtr.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	05 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & w.CO2	MR
	3) ISI marking	N/A	N/A	N/A

4/7

6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

J

1/10

	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School2013/789 dated 22/02/2013, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- A. D.O. (CC)

~~DOTC~~

~~27/9/22~~

~~Dy. Commr~~

F.T. please.  
Ravinder Singh  
27/9/22

~~ADDO (CC)~~

As proposed in para for  
1000000 and 2000000000

~~Dy. Commr~~

Ravinder Singh  
27/9/22

F.P. wing

Ravinder Singh  
11/9/22