

C-28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No.F6 /DFS/MS /2022 /Hostel/ 408

Dated 6 / 9 /2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Mata Kasturba Girls Hostel** located at **47 & 49, Harijan Sevak Sangh, Kingsway Camp, Delhi-110009** comprised of **02 blocks- ground & first floor but hostel is running at ground floor with 09 students rooms only** owned and occupied by the **Mata Kasturba Girls Hostel** was issued Fire Safety Certificate vide this office letter no. **F6/DFS/MS/2019/GH/1229 dated 07.06.2019** The premise was re inspected by the officer concerned of this department on **26.08.2022** in the presence of **Sh. Sanjay Rai (Secretary)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore, deemed complied with the requirement under rule 33 of Delhi Fire Service Rules, 2010 and the building is fit for occupancy class **Group A-3 Residential (Hostel)** with effect from ~~6/9/22~~ for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ....6/9/22.... at New Delhi by

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph-011-23414250  
of e p

Copy to:-

1. Mata Kasturba Girls Hostel located at 47 & 49, Harijan Sevak Sangh, Kingsway Camp, Delhi-110009.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

- 1 Name & address of the building : Mata Kasturba Girls Hostel, 47 & 49, Harijan Sevak Sangh, Kingsway Camp, Delhi 110009
- 2 Composition of building : 02 blocks, Ground & first floor each **but hostel is running at ground floor with 09 student rooms only**
- 3 Type of Occupancy : Residential ( Group A-3)
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6/DFS/MS/2019/GH/1229 dated 07.06.2019
- 6 Fire Safety directives letter No : Nil
- 7 Date of inspection : 26.08.2022
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Sh. Sanjay Rai (Secretary)
10. Year of Construction : 2002
11. Applicant's letter No. : Letter No. Nil Dated:04.08.2022 & DFS Dairy No.4168 Dated:08.08.2022

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Pat-4 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.5m	MR(old case)
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits Ground Floor Only</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA

5	<b>Fire Extinguishers</b>			
	• Total numbers	05nos	06nos	MR
	• Types	ABC Co2	ABC 6	MR
	• ISI marking	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			

N/25

	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 1229 dated 07.06.2019 under rule 37 of the Delhi Fire Service Rules 2010.

~~DO (W2)~~

~~Signature~~  
29/08/2022  
~~ADO (W2)~~

31/8/2022

~~ADO/R.N~~

As approved, F.S. letter is put up for your signature pl.

Copy  
Signature of the Inspecting Officer  
Name: - C.L. Meena  
Designation:- ADO/RN

Copy  
10/09/2022  
cont. ADO (W2)  
P.T.O.