

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**



No. F 6/DFS/MS/School/2022/SZ/1021

Dated 16.1.22/2022

FIRE SAFETY CERTIFICATE

Certified that **Guru Harkrishan Public School**, located at **Hemkunt Colony, New Delhi 110048** comprised of basement, ground plus two upper floors owned/occupied by **Guru Harkrishan Public School** was issued FSC by this department vide letter no. F6/DFS/MS/School/2019/SZ/1474 dated 18/07/2019. The premises was re-inspected by officer concerned of this department on 05/09/2022 in presence of Mr. Bhupenderjeet Singh Gulshan (Principal) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the 16/9/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/9/2022 at New Delhi by


**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER**


Copy to: -

1. Guru Harkrishan Public School, located at Hemkunt Colony, New Delhi 110048
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Guru Harkrishan Public School, Hemkunt Colony, New Delhi 110048		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1474 dated 18/07/2019		
6	Fire Safety Directives Letter No	F 16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	05-09-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Bhupenderjeet Singh Gulshan (Principal)		
10	Year of construction	1993		
11	Applicant letter No.	GHPS/HK/2223/9668 dated 23-08-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	20 mtr	20 mtr	MR
	• Gate width	4 mtr	5 m x 2	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 No	03 Provided	MR
	➤ Basement floor	02 No	03 Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	1.40 mtr each	MR
	➤ Basement floor	1.5m / 0.75m	1.40 mtr each	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	03 Provided	MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	30 Nos	30 Nos	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	02 Nos	Provided	MR
	• Length of hose-reel hose	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-

N/My




	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box 	02	02	MR
		02	02	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey Pump output Jockey Pump head Standby Pump output Standby Pump head Auto Starting/Manual Stopping Pump house access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump Power supply Auto starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450 & 180 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire Service Inlet Access to tank Overhead tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		15,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Fireman's switch Lift signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			

• Detector system panel	-NA-	-NA-	-NA-
• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-
20. Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No Fo/DFS/MS/School/2019/SZ/1474 dated 18/07/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name Sh. Rajesh Kumar
 Design ADO (BCP)

Dr. CEO (SZ)

F.T.

~~AND F.T.P.~~

As approved, F.T. letter is put up for your signature.

18/7
1319

Dr. CEO (SZ)

M.S. cell