



C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI


No: F.6/DFS/MS/School/WZ/2022 /1016

Dated: 15/9/22

FIRE SAFETY CERTIFICATE

Certified that the **M.C Primary Co- Education School** Located at **Bharat Nagar, New Delhi - 110052** comprised Ground + 01 Upper floor, was issued FSC vide letter No. F.6/DFS/MS/WZ/2019/844 dated 16/04/2019, the premises was re-inspected by the officer concerned by this department on 02/09/2022 in the presence of **Smt. Promila Jain (Principal)** and observed that fire prevention and fire safety arrangements provide in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular no. 3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "Educational Building" Group-B, as above with effect from 15/9/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition printed overleaf.

Issued on 15/9/22 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. M.C. Primary Co – Education School, located at Bharat Nagar, New Delhi-110052.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Co-Education School Located at Bharat Nagar, New Delhi - 110052.
2. Type of Occupancy : Educational (Ground + 01 upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/D/S/MS/WZ/2019/844 dated 16/04/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 02/09/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Smt. Promila Jain (Principal)
9. Year of Construction : 2018 (As Per Prev. Insp. Report dated: - 03/04/2019s)
10. Applicant's letter No. : Letter no. nil, Outdoor diary dated: - 08/08/2022

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | DOE 3298-3398 dated 01/03/2011 As Per Pre. Insp. Report dtd:- 03/04/2019 | Provided at site | Remarks MR/NMR |
|--------|---|--|------------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 5 mts | Provided | MR |
| | • Gate width | 300 m | Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5 mts | 1 x 150cm & 1 x 124 cm | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | e. No. of continuous staircases to terrace | 01 | Provided | MR |
| | f. Width of Corridor | 1.5 m | 210 cm Provided | MR |
| | g. Door Size | 1 mts | 112 cms provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 05 nos. | Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |

| | | | | |
|----|--|----------|----------|----|
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/ Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|--|----|----|----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules DOE Circular no. 3298-3398 dated 01/03/2011, the NOC issued vide letter no. F6/DFS/MS/WZ/2019/844 dated: - 16/04/2019 renewal under 35 of the Delhi Fire Service Rules 2010 is recommended.

297/ADO/MN
07/9/2022
659/DO/WD
01.9/9/2022

~~DO (just)~~

~~SP-1~~
07/09/2022

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~DO~~
07/09/2022

~~DO (w2)~~

~~12/9/2022~~

~~ADO (MN)~~

Sir, F. T is out up for your kind personal & signature please.

~~DO (w2)~~

~~SP-1~~
12/9/2022

~~14/9/2022~~

MSJ all