



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F.6/DFS/MS/School/WZ/2022/11017

Dated: 15/9/22


FIRE SAFETY CERTIFICATE

Certified that the **Munni Mayaram Jain Public School** Located at **Block-P P, Pitampura, New Delhi - 110034** comprised Ground floor Only, was issued FSC vide letter No. F.6/DFS/MS/WZ/2019/32 dated 07/01/2019, the premises was inspected by the officer concerned by this department on 24/08/2022 in the presence of **Smt. Alka Jain (Principal)** and observed that fire prevention and fire safety arrangements provide in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular no. 262-362 dated 17/01/2005 and that the premises is fit for occupancy class 'Educational' Group-B, with effect from, for a period of ^{15/9/22} three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below .

Issued on at New Delhi.

15/9/22


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone


15/9/22

Copy to: -

1. The Principal, Muni Mayaram Jain Public School located at Block- P P, Pitampura, New Delhi-110034.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

r/12

INSPECTION REPORT

1. Name & address of the building : Munni Mayaram Jain Public School Located at Block-P P, Pitampura, New Delhi – 110034.
2. Type of Occupancy : Educational (Ground floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/2019/32 dated 07/01/2019
5. Fire Safety directives letter No : DOE 262-362 dated 17/01/2005
6. Date of inspection : 24/08/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Smt. Alka Jain (Principal)
9. Year of Construction : 1989 (As Per Prev. Insp. Report dated: - 17/12/2018)
10. Applicant's letter No. : Email dated: - 21/07/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 262-362 dated 17/01/2005 As Per Pre. Insp. Report dtd:- 17/12/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 355cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 mts	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 08 nos. CO₂, ABC type ISI marked 	<ul style="list-style-type: none"> 12 Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR

21

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

16 Provision of Lifts.

• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of Lift lobby	NA	NA	NA
• Communication In lift Car	NA	NA	NA
• Fireman's Grounding Switch	NA	NA	NA
• Lift Signage	NA	NA	NA

17 Standby power supply

18 Refuge Area.	NA	NA	NA
-----------------	----	----	----

➤ Total Area	NA	NA	NA
➤ Location	NA	NA	NA

19 Fire Control Room

• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Batter backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA

20 Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA
---	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2019/32 dated: - 07/01/2019 renewal under 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (wast)~~

~~Signature~~
25/8/22

76/ADO/MN
25/8/2022

~~Signature~~
DO (w)

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~Signature~~
DO (w)

~~Signature~~
26/9/22

~~Signature~~
ADO/MN

Sir, F. T is put up for your kind personal & Signature please.

~~Signature~~
DO (w2)

~~Signature~~
02/9/22

~~Signature~~
MS/ell

~~Signature~~
14/9/22