



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/Hospital/WZ/2022/409

Dated: 19/09/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Bhatia Global Hospital & Endosurgery Institute** Located at, **305, 307, 308 Ambica Vihar, New Delhi-110087** comprised of Basement + Ground + 03 Upper Floors was issued Fire Safety Certificate vide Letter No. **F6/DFS/MS/Hospital/2019/WZ/1326** dated **21.06.2019**. The said premises was re-inspected by the officer concerned of this department on 19.08.2022 in the presence of Sh. Manoj (MR Executive) and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and that the premises/building is fit for occupancy class "Institutional Building" Group C Sub Division C-1 with effect from 19/09/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 19/09/2022 at New Delhi by.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. Sh. R S Bhatia (Chairman), Bhati Global Hospital & Endosurgery Institue, New Delhi-110087..

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolt /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of building Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

## INSPECTION REPORT

1. Name & address of the building: **Bhati Global Hospital & Endosurgery Institue** Located at **305-307-308, Ambica Vihar, Paschim Vihar, New Delhi-110087**
2. Type of Occupancy : Institutional (Basement + Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC:F6/DFS/MS/Hospital/2019/WZ/1326 dated 21.06.2019
5. Fire Safety directives Letter No. : F6/DFS/MS/2012/85 dated 10.01.2012
6. Date of inspection : 19.08.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Manoj (MR Executive)
9. Year of Construction : 2001
10. Applicant's letter No. : Nil dated 20.07.2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Directive letter dated 10.01.2012 Requirements/ as per FSC dated 21.06.2019 | Provided at site | Remarks MR/NMR |
|------|---|---|------------------|----------------|
| 1.   | Access of building  |   |                  |                |
|      | • Road width  | 12 m  | Provided         | MR             |
|      | • Gate width  | 05 m  | Provided         | MR             |
|      | • Width of internal road                                    | NA  | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |   |                  |                |
|      | a. Number of staircases                                     |   |                  |                |
|      | • Upper floors  | 02  | Provided         | MR             |
|      | • Basements   | 02  | Provided         | MR             |
|      | b. Width of staircases                                      |   |                  |                |
|      | • Upper floors  | 2 m   | 2 m x 2          | MR             |
|      | • Basements   | 2 m   | 2 m x 2          | MR             |
|      | c. Protection of exits                                      |   |                  |                |
|      | • Fire check door   | NA  | NA               | NA             |
|      | • Pressurization  | NA  | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | 01  | Provided         | MR             |
|      | e. Width Of Corridor  | Old Case  | Old Case         | Old Case       |
|      | f. Door Size  | Old Case  | Old Case         | Old Case       |
| 3.   | Compartmentation  |   |                  |                |
|      | • Fire check door   | Required  | Provided         | MR             |
|      | • Sealing of electrical shafts                              | Required  | Provided         | MR             |
|      | • Fire Rating of shaft door                                 | NA  | NA               | NA             |
|      | • Water Curtain   | NA  | NA               | NA             |
|      | • Fire Dampers  | NA  | NA               | NA             |
| 4.   | Smoke managements System                                    |   |                  |                |
|      | • Basements   | NA  | NA               | NA             |
|      | • Upper floors  | NA  | NA               | NA             |
| 5.   | Fire Extinguishers  |   |                  |                |
|      | • Total numbers   | 10 nos.   | 12 nos.          | MR             |
|      | • Types   | DCP & CO2   | Provided         | MR             |
|      | • IS marking  | ISI marked  | Provided         | MR             |
| 6.   | First - Aid Hose Reels                                      |   |                  |                |
|      | • Total numbers on each floor                               | 01 at each floor  | Provided         | MR             |
|      | • Length of hose reel hose                                  | 30 m  | Provided         | MR             |
|      | • Nozzle diameter   | 5 mm  | Provided         | MR             |

|     |  |   |          |    |
|-----|--|---|----------|----|
| 7.  | Automatic fire detection and alarming system   |   |          |    |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>  | Smoke                                   | Provided | MR |
|     |  | Ground floor                            | Provided | MR |
|     |  | NA                                      | NA       | NA |
|     |  | Required                                | Provided | MR |
|     |  | Required                                | Provided | MR |
| 8.  | MOEFA  | Required                                | Provided | MR |
| 9.  | Public Address System  | NA                                      | NA       | NA |
| 10. | Automatic Sprinkler System   |   |          |    |
|     | <ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>  | Required                                | Provided | MR |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
| 11. | Internal Hydrants:   |   |          |    |
|     | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>   | 150 mm                                  | Provided | MR |
|     |  | 01 each floor                           | Provided | MR |
|     |  | 01 each floor                           | Provided | MR |
| 12. | Yard Hydrants  |   |          |    |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>   | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
| 13. | Pumping Arrangements:  |   |          |    |
|     | <ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul> | 1620 lpm                                | Provided | MR |
|     |  | 75 m                                    | Provided | MR |
|     |  | 02                                      | Provided | MR |
|     |  | 180 lpm                                 | Provided | MR |
|     |  | 75 m                                    | Provided | MR |
|     |  | 1620 lpm                                | Provided | MR |
|     |  | 75 m                                    | Provided | MR |
|     |  | Required                                | Provided | MR |
|     |  | Required                                | Provided | MR |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
| 14. |  | Captive water Storage for firefighting: |          |    |
|     | <ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>  | 50,000 litres                           | Provided | MR |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
|     |  | 10,000 litres                           | Provided | MR |
| 15. | Exit Signage   | Required                                | Provided | MR |
| 16. | Provision of Lifts   |   |          |    |
|     | <ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>  | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |
|     |  | Required                                | Provided | MR |
|     |  | Required                                | Provided | MR |
|     |  | Required                                | Provided | MR |
| 17. | Standby power supply   | Required                                | Provided | MR |
| 18. | Refuge Area  |   |          |    |
|     | <ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>   | NA                                      | NA       | NA |
|     |  | NA                                      | NA       | NA |

|     |  |    |    |    |
|-----|--|----|----|----|
| 19. | Fire control room  | NA | NA | NA |
|     | ➤ Detector system panel  | NA | NA | NA |
|     | ➤ Flow Switch Panel  | NA | NA | NA |
|     | ➤ PA System Panel  | NA | NA | NA |
|     | ➤ Battery backup   | NA | NA | NA |
|     | ➤ Building Floor Plans   | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcoming issued vide letter no. F6/DFS/MS/Hospital/2022/WZ/1567 dated 29.06.2022 are rectified.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/Hospital/2019/WZ/1326 dated 21.06.2019 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007

Accordingly DFA is prepared put up for approval please.

*[Signature]*  
21/8/22  
Aman Kumar Lathar  
ADO (JWP)

~~20/WZ~~  
399  
2/9/2022

~~DFS (WZ)~~  
*[Signature]*  
02/9/2022  
15/9/2022

~~MS/DFP~~  
F.F. letter is put-up for signature P1

~~DCFO (WZ)~~  
*[Signature]*  
19/9/2022

*[Signature]*  
16/9/22  
AND GWP

MS/DFP