

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2022/NDZ/ 1031

Dated: 19/9/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School located at B-2, Yamuna Vihar, Delhi-110053, building comprised of One Block Ground plus Three Upper Floor & Two Blocks Ground plus One Upper Floor only owned / occupied by Govt. Girls Sr. Sec. School, was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/1519 (for G+3 Block) Dated 24/07/19 & F6/DFS/MS/School/2018/NDZ/2695 Dated 13/12/18 (for G+1 Blocks). The School building was re-inspected by the officer concerned of this department on 07/09/2022 in presence of Smt. Asha (Head of School) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the rule 33 of the Delhi Fire Service rules 2010 and found that the building is fit for occupancy class "Educational" (Group-B) with effect from 19/9/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

**Issued on 19/9/22 at New Delhi by.**

(S.K. DUA)

**DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE.**

Copy to :-

1. The Principal, Govt. Girls Sr. Sec. School located at B-2, Yamuna Vihar, Delhi-110053.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Govt. Girls Sr. Sec. School, B-2, Yamuna Vihar, Delhi-11005.
2. Building is comprised of : G + 1 ( 2-Blocks) & G+3 (1-Blocks)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/NDZ/1519 Dated 24/07/19  
(for G+1) & F6/DFS/MS/School/2018/NDZ/2695 dated 13/12/2018 (For G+3)
6. Fire Safety directives Letter No.: DFS Act 2007 & Rules 2010 / NBC (Part-IV)
7. Date of inspection : 07/09/2022
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer  
from the building side : Smt. Asha Jakhmala (H.O.S.)
10. Year of Construction : 1988 & 2018
11. Applicant's letter received through email ID-ggssb2yamunavihar@yahoo.com dated 29/08/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part IV) Requirements	Provided at Site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	7.50 mtr	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 nos. (G+1 Block) 02 nos. (G+1 Block) 02 nos. (G+3 Block)	05 nos. (G+1) 02 nos. (G+1) 02 nos. (G+3)	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr(each blocks)	1.50 mtr each (for G+1 Blocks) 1.86 mtr (G+3 Block)	MR ✓
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2 for G+1 blocks & 1 for G+3 blk	Provided	MR ✓
	e. Width Of Corridor	1.50 mtrs.	Provided	MR ✓
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	28 nos.	37 nos.	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	MR

*A.K. Jaiswal*

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1. (for G+3 blk only)	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM (for G+3 blk only)	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
➤ Power supply	Required	Provided	MR	
➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR



16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/NDZ/1519 Dated 24/07/19 (for G+1) & F6/DFS/MS/School/2018/NDZ/2695 dated 13/12/2018 (For G+3) renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok*  
13/09/2021  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East Division)

~~Dy. CFO (NDZ)~~ F.T. please.  
*Riv*  
14/09/21

~~DO (ED)~~ F.T. is put up for sign. please.

~~Dy. CFO (NDZ)~~

*Riv*  
16/09/21

F.P. wing

*Ashok*  
15/09/2021