



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
जाजादीक
अमृत महोत्सव

No. F6/DFS/MS/WZ/2022/ 52

Dated: 14/9/22

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Forever Restaurant and Party Hub (A Unit of Forever Banquet and Hospitality Group)** Located at **Property no. 20, Paschim Vihar Extension, New Delhi-110063, is running on Ground Floor** in a building comprised of Basement + Ground + 02 Upper Floors owned/ occupied by **M/s. Forever Restaurant and Party Hub (A Unit of Forever Banquet and Hospitality Group)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 24.08.2022 in the presence of Sh. Manish Puri (Manager) and that the said building is fit for occupancy class "Assembly" Group D (Restaurant) for Ground floor only with effect from 14/9/22 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on ...14/9/22... at New Delhi by.

(Atul Garg)
Director

14/9/22
09/09/22

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.
3. Sh. Manish Puri, M/s. Forever Restaurant & Party Hub (A Unit of Forever Banquet & Hospitality Group), Located at Property no. 20, Paschim Vihar Extension, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. **This FSC is valid for Ground floor only.**
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The basement shall be used as per BBL.

INSPECTION REPORT

M-4

Name & address of the building	M/s. Forever Restaurant & Party Hub, Located at Property no. 20, Paschim Vihar Extension, Delhi-110063		
Type of Occupancy	Restaurant (Class - D, Assembly)		
Type of case	New, Restaurant is running at Ground floor only (building comprised of Basement + Ground + 02 Upper floors only)		
Details of previous NOC	Nil		
Fire safety directives letter No	As per UBBL/NBC (Part-IV)		
Date of inspection	24.08.2022		
Name of the inspecting Officers :	Aman Kumar Lathar, ADO (JWP)		
Name and designation of officers from the building side	Sh. Manish Puri (Manager)		
Year of construction	2000		
Applicant's online application no.	2022063013803 dated 05.07.2022		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to building			
	1) Road width	6 m	Provided	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	NA		1 NA
	2. basements	NA	NA	NA
	b. Width of staircase			
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NR	NR	NR
	d. No. of continuous staircase to terrace	NR	NR	NR
	e. Width of corridor	NR	NR	NR
	f. Door size	1.5 m x 2	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	NR	NR	NR
	3. Fire Rating of shaft door	NR	NR	NR
	4. water curtain	NR	NR	NR
	5. Fire dampers	NR	NR	NR
4	Smoke Management system.			
	basement	30 a/c per hour	NR	NR
	upper floors	12 a/c per hour	Natural Ventilation	MR

De

N-5

5	Fire Extinguishers			
	total numbers	05 nos. ABC,	Provided	MR
	Types	CO2 & Foam ISI	Provided	MR
	ISI marking	Marked	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	NR	NR	NR
	location of Main Panel	NR	NR	NR
	location of Repeater panel	NR	NR	NR
	Alternate source of power	NR	NR	NR
	hooter's location	NR	NR	NR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	basement	NR	NR	NR
	upper floors	NR	NR	NR
	sprinkler above false ceiling	NR	NR	NR
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	1	Provided	MR
	Hose Box	1	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	NR	NR	NR
	Hose box	NR	NR	NR
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	NR	NR	NR
	b. Head of main pump	NR	NR	NR
	c. Number of main pumps	NR	NR	NR
	d. jockey pump out put	NR	NR	NR
	e. jockey pump head	NR	NR	NR
	f. Standby Pump output	NR	NR	NR
	g. Stanby Pump head	NR	NR	NR
	h. Auto Starting/Manual stopping	NR	NR	NR
	pump house access			
	2. Terrace level			
	a. Discharge of pump	450 lpm	Provided	MR
	b. head of the pump	40 m	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	NR	NR	NR
	a. Draw-off connection	NR	NR	NR
	b. fire service inlet	NR	NR	NR
	c. Access to tank	NR	NR	NR
	Over head tank Capacity	20,000 ltrs	Provided	MR

De

MR
MR
MR

M-6

	Exit Signage.	Required	Provided	MR
	Provision of lifts.			
	a. Pressurization of lift shaft	NR	NR	NR
	b. pressurization of lift lobby	NR	NR	NR
	c. communication in lift car	NR	NR	NR
	d. Fireman's grounding switch	NR	NR	NR
	e. Lift signage	NR	NR	NR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	NR	NR	NR
	location	NR	NR	NR
19	Fire control room			
	a. Detector system Panel	NR	NR	NR
	b. Flow switch Panel	NR	NR	NR
	c. PA system Panel	NR	NR	NR
	d. Batter backup	NR	NR	NR
	e. Building floor plans	NR	NR	NR
20	Special Fire Protection systems for protection of special risks, if	NR	NR	NR

The fire protection systems provided in the building were checked and found functional at the time of inspection.
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirement under the rules, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act, 2009.

(Signature)
 Aman Kumar Lathar, ADO (JWP)

~~DO/W~~

Kindly appraise the use of basement floor & upper floor as the owner of the restaurant have applied for basement & ground floor for restaurant use.

D.O. WEST/366
 DATED: 25/8/2022

(Signature)
 ADO (JWP)

(Signature)
 25/8/2022

- ① Basement floor is using for storage.
- ② Upper floors found vacant during inspection.
- ③ Undertaking from owner side also inclosed/Placed opposite.

(Signature)
 27/8/22
 ADO (JWP)

~~DO/W~~

(Signature)
 29/8/2022

(Signature)
 Des (ns)

Mechanical
 what about ventilation

D.O. WEST/366
 DATED: 29/8/2022

(Signature)
 ADO/West

(Signature)
 ADO (JWP) P.F.O.,

(Signature)
 11/9/2022