

527

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS /MS/2022 /School/ 1035

Dated: 20/9/2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Senior Secondary School (I.D No-1309265)** located at **Qadipur, Delhi-110036** comprised of **ground & 03 upper floors only** owned/ occupied by **Govt. Girls Senior Secondary School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2019/1770 dated 13.09.2019** the premise was re-inspected by the officer concerned of this department on **12.09.2022** in the presence of **Mrs. Rajwanti (Teacher)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **20/9/22** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **20/9/22** at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250
H.C. B

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Girls Sr. Sec. School located at Qadipur, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School (ID -1309265), Qadipur, Delhi-110036.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 03 upper floors only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2019/1770 dated: 13.09.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 12.09.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mrs. Rajwanti (Teacher)
10. Year of Construction : 2017
11. Applicant's letter No. : Online E-mail I'd dated: 01.09.2022

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1 m	1.15m double door	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	24nos	24nos	MR
	• Types	ABC/Co2	ABC-12/Co2-12	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 each floor 30 m 5mm	02 each floor 30m 5mm	MR MR MR
	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A NA NA N/A N/A N/A N/A 450lpm 40m Required Required	N/A N/A N/A NA NA N/A N/A N/A 450 lpm x 02 40m Provided Provided	N/A N/A N/A NA NA N/A N/A N/A MR MR MR MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000 ltr Required	1,00,000 ltr. NA NA NA 10,000 ltr. Provided	NA NA NA NA MR MR
15	Exit Signage.			

16	Provision of Lifts.				N/A
	•	Pressurization of Lift Shaft	N/A	N/A	N/A
	•	Pressurization of Lift lobby	N/A	N/A	N/A
	•	Communication In lift Car	N/A	N/A	N/A
	•	Fireman's Grounding Switch	N/A	N/A	N/A
	•	Lift Signage	N/A	N/A	N/A
17	Standby power supply		N/A	N/A	N/A
18	Refuge Area.				N/A
	➤	Total Area	N/A	N/A	N/A
	➤	Location	N/A	N/A	N/A
19	Fire Control Room				N/A
	•	Detector System Panel	N/A	N/A	N/A
	•	Flow Switch Panel	N/A	N/A	N/A
	•	PA System Panel	N/A	N/A	N/A
	•	Batter backup	N/A	N/A	N/A
	•	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-IV, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.1770 dated 13.09.2019.

~~DO (A/R)~~

~~By cfo (wz)~~
13/09/2022

14/9/2022



Signature of the Inspecting Officer
Name: - C.L. Meena
Designation: - ADO/RN

~~ADO/R-N~~

As approved, F.T. letter is kept up for your signature pl.

~~By cfo (wz)~~

20/9/2022


16/09/2022
ADO (RN)

ms/cdf