



FIRE SAFETY CERTIFICATE

Certified that the **M/s Haldiram Marketing Pvt. Ltd** located at Plot No. **B-1, F-10, M.C.I.F, Main Mathura Road, New Delhi 110044**, comprised of **Basement + Ground floor + 02 upper floor** was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Industrial/2019/SZ/2010 dated 21.10.2019. The building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 09.09.2022 in the presence of Mr. Sanjeev and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises (**Basement + Ground floor + 02 upper floor**) is fit for occupancy of Group **G "Industrial Building"** with effect from 15/9/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 15/9/22 at New Delhi by

(**Sunil Chawdhary**)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New DeDelhi-24.
2. M/s Haldiram Marketing Pvt. Ltd located at Plot No. B-1, F-10, M.C.I.E, Main Mathura Road, New Delhi 110044.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. Basement shall used as per NBC/UBBL.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Haldiram Marketing Pvt. Ltd located at Plot No. B-1, F-10, M.C.I.F, Main Mathura Road, New Delhi 110044.			
2	Building is comprised of	Basement + Ground + 02 upper floors.			
3	Type of occupancy	Industrial Group-G			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/Industrial/2019/SZ/2010 dated 21.10.2019			
6	Fire safety direction letter no.	F6/DFS/MS/2001/642 dated 18/04/2001			
7	Date of inspection	09.09.2022			
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)			
9	Name of the designation of officer From the building side	Mr. Sanjeev			
10	Year of construction	2001			
11	Applicant's letter no.	Email dated 22.08.2022			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements Old NOC	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6.0 mtrs	Provided	MR
	B	Gate width	3.3 mtrs	Provided	MR (Old case)
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	2 nos.	2 nos.	MR
		b) Basements	2 nos.	03 nos.	MR
	B	Width of the staircase:			
		a) Upper floors	1.5 mtrs each	1.5 to 2.07 mtrs & 1.90 mtrs	MR
		b) Basements	1.5 mtrs each	1.80, 1.60 & 1.30 mtrs	MR
	C	Protection of Exits			
		a) Fire check door	Required	Provided	MR
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	02 nos	2 nos	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	1.5 mtrs	1.5 mtrs (Final Exit)	MR
3	Compartmentation:				
	A	Fire check doors	Required	Provided	MR
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	Mechanical/ Natural	Exhaust fan	MR
	B	Upper floors	Mechanical/ Natural	Exhaust fan	MR
5	Fire Extinguishers				
	A	Total numbers	14 nos.	16 nos	MR
	B	Types	ABC / CO ₂	ABC / CO ₂ type	MR
	C	ISI marking	ISI marking	Provided	MR

6	First Aid Hose Reel				
	A	Total no. at each floor	02 nos.	02 nos.	MR
	B	Length of hose reel	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of detectors	Smoke/Heat	Smoke/Heat	MR
	B	Location of main Panel	At Ground floor	Ground floor	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	Required	Provided	MR
	E	Hooter's location	Required	Provided	MR
8	MOEFA				
			Required	Provided	MR
9	Public Address System				
			Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper floor	Required	Provided	MR
	C	Sprinklers above false ceiling	Required	Provided	MR
11	Internal Hydrants				
	A	Size of the riser/down comer	100 mm	100 mm	MR
	B	No. of hydrants per floor	02 nos	02 nos	MR
	C	Hose box	02 nos	02 nos	MR
12	Yard Hydrants				
	A	Total no. of hydrants	04 nos.	04 nos.	MR
	B	Hose box	04 nos.	04 nos.	MR
13	Pumping Arrangements				
	A	Ground Level			
		a) Discharge & head of main pump	2280 LPM & 70 m	2280 LPM & 70 m	MR
		b) Number of main pump	1 no.	1 no.	MR
		c) Discharge & head of jockey pump	180 LPM & 70 m	180 LPM & 70 m	MR
		d) Discharge & head of Standby pump	2280 LPM & 70 m	2280 LPM & 70 m	MR
		e) Auto starting/ manual stopping	Required	Provided	MR
	B	Terrace Level			
		a) Discharge of terrace pump	900 LMP	900 LMP	MR
		b) Head of terrace pump	35 mtrs	35 mtrs	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	10,0000 Ltrs	10,0000 Ltrs	MR
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	20,000 Ltrs	20,000 Ltrs	MR
15	Exit Signage				
			Required	Provided	MR
16	Provision of lift :				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided (125KVA)	MR

M/23

18 Refuge Area				
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19 Fire Control Room				
A	Fire detection system panel	Required	Provided	MR
B	Flow switch panel	Required	Provided	MR
C	P a system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20 Special Fire Protection for special risk if any				
A	Special fire protection system for protection of special risk, if any:			NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/Industrial/2019/SZ/2010 dated 21.10.2019 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

Rk
12/9/22

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

F.T.

Dy. CFO (SZ)

ADO (MRN)

FT is put up ple

Rk
15/9/22

Dy. CFO (SZ)

M.S.