



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/INDL/NDZ/2022/ 412

Dated : 20/09/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Industrial Building at Plot no. 254 FIE, Patparganj Ind. Area, Delhi-110092 comprised of Basement + Ground + 02 Upper floors owned/occupied by Amrish Creations was granted FSC by this department vide letter No. F6/DFS/MS/INDL/2019/NDZ/1287 dated 17/06/2019. The premises was inspected by the officers concerned of this department on 10/09/2022 in the presence of Mr. Naeem Khan (Manager) & Mr. Amrish Kumar Goel (Owner) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Industrial Building" (Group G) with effect from ~~20/9/2022~~ for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 20/09/2022 at New Delhi by.


(S.K Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Mr. Amrish Kumar Goel (Owner),
M/s Industrial Building at Plot no. 254 FIE,
Patparganj Ind. Area, Delhi-110092.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Basement shall be used strictly as per Building By-Laws.

- N/14 -

INSPECTION REPORT

75
Azadi Ka
Amrit Mahotsav

1. Name & address of the building : M/s Industrial Building at Plot no. 254 FIE , Patparganj Ind. Area, Delhi-110092
2. Type of occupancy : Industrial Building
(Basement + Ground + 02Upper floor)
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/INDL/2019/NDZ/1287 dated 17/06/2019
5. Fire safety directives No. : NBC Part-IV
6. Date of inspection:- : 25/08/2022
7. Name of the inspecting officer : Sh. A.K. Jaiswal (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer From the building side : Mr. Naeem Khan (Manager) & Mr. Amrish Kumar Goel (Owner)
9. Year of construction : 1998
10. Applicant's letter No : nil dated 05/09/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement BBL 1983	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	02 No.	MR
	2. Basements	02 No.	02 No.	MR
	B. Width of staircase			
	1. Upper floors	1.25 m (1.30 m & 1.0m)	1.30 mtr & 1.0 mtr.	MR (old accepted)
	2. Basements	1.25 m (1.30 m & 1.0m)	1.30 mtr & 1.0 mtr.	MR (old accepted)
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 no.	01 no.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	09 Nos.	12 Nos.	MR

AB



- N/15 -

75
Azadi Ka
Amrit Mahotsav



	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	01 no.	01 no.	MR
	3) Hose box each floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	i) Pump house access	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	2 nos. 450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

MD



	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltr.	15,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter F6/DFS/MS/INDL/2019/NDZ/1287 dated 17/06/2019, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

merls
TRK
Signature of the Inspecting Officer
Name :- M.K. Sharma
Designation :- ADO (LN)

A.K. Jaiswal
13/09/2022
Signature of the Inspecting Officer
Name :- A.K. Jaiswal
Designation :- DO (ED)

BY CFO (NDZ)

F.T. please.

ADO (LN)

king
15/09/22

F.T. letter is put up for sig pl

DEFO (NDZ)

king
20/09/22

F.P. wing

merls
19/9