

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/ 251

Dated..7.../9.../2022

FIRE SAFETY CERTIFICATE

Certified that **M/s KAKAPO** located at Commercial Area, **H-5/5, 2nd Floor**, Ward No. 1, Kalka Das Marg, Mehrauli, New Delhi-110030 in the building comprised of ground plus Two Upper floor owner/occupied by Black Pants Hospitality LLP was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2019/SZ/2375 dated 27/12/2019. The restaurant premise was re-inspected by the officer concerned of this department on 23/08/2022 in the presence of Mr. Shubhankar Gupta (GM) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for (**Restaurant at 2nd Floor Only**) occupancy **Class D "Assembly Building"** Restaurant as above with effect from ...7.../9...2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7 / 9 /2022 at New Delhi by



(**SUNIL CHAUDHARY**)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -



1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-110016 (Ref. MHA Portal ID 202052110831 dated 26/07/2022)
2. **M/s KAKAPO** located at Commercial Area, **H-5/5, 2nd Floor**, Ward No. 1, Kalka Das Marg, Mehrauli, New Delhi-110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

N-6

	Name & Address of the Building	M/s KAKAPO (A unit of Black Pants Hospitality LLP), Commercial Area at H-5/5, 2 nd Floor, Ward No. 1, Kalka Das Marg, Mehrauli, New Delhi-110030		
2	Type of Occupancy	Group-D, "Assembly"		
3	Building Comprised of	Ground + Two Upper Floors. (Restaurant running at 2 nd Floor Only)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/2375 dated 27/12/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23-08-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shubhankar Gupta (GM)		
10	Year of construction	1960		
11	Applicant letter No.	MHA Portal ID 202052110831 dated 26/07/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC-2016 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	Abut on Road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	2 m & 1 m	2 m & 1.5m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2m & 1.5m	2m & 1.52 m	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Restaurant Area	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	04 Nos	04 Nos	MR
	• Types	ABC/CO2	ABC & CO2	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A

N-7

10	Automatic Sprinkler System	Basement	N/A	N/A	N/A
		Upper floors/ Restt. Area	Required	Provided	MR
11	Internal Hydrants.	Sprinkler above false ceiling	N/A	N/A	N/A
		Size of Riser/Down-comer	100 mm	Provided	MR
12	Yard Hydrants.	Number of Hydrant per floor	One	Provided	MR
		Hose box.	One	Provided	MR
13	Pumping arrangements.	Total number of hydrants.	N/A	N/A	N/A
		Hose box.	N/A	N/A	N/A
13	Pumping arrangements.	Ground Level			
		Discharge of main pump.	N/A	N/A	N/A
		Head of main pump.	N/A	N/A	N/A
		Number of main pumps.	N/A	N/A	N/A
		Jockey Pump output.	N/A	N/A	N/A
		Jockey Pump head.	N/A	N/A	N/A
		Standby Pump output.	N/A	N/A	N/A
		Standby Pump head.	N/A	N/A	N/A
		Auto Starting/Manual Stopping.	N/A	N/A	N/A
		Pump house access.	N/A	N/A	N/A
		Terrace Level			
		Discharge of pump.	450 LPM	Provided	MR
Head of pump.	40m	Provided	MR		
Power supply.	N/A	N/A	N/A		
Auto starting of pump.	N/A	N/A	N/A		
14	Captive water storage for firefighting.	Underground tank capacity.	N/A	N/A	N/A
		Draw-off connection.	N/A	N/A	N/A
		Fire Service Inlet.	N/A	N/A	N/A
		Access to tank.	N/A	N/A	N/A
		Overhead tank capacity.	20,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts.	Pressurization of lift shaft.	N/A	N/A	N/A
		Pressurization of lift lobby.	N/A	N/A	N/A
		Communication in lift car.	N/A	N/A	N/A
		Fireman's switch.	N/A	N/A	N/A
		Lift signage.	N/A	N/A	N/A
		Standby Power Supply	Required	Provided	MR
18	Refuge Area	Total area	N/A	N/A	N/A
		Location	N/A	N/A	N/A
19	Fire Control Room.	Detector system panel.	N/A	N/A	N/A
		Flow switch panel.	N/A	N/A	N/A
		PA system panel.	N/A	N/A	N/A
		Battery backup.	N/A	N/A	N/A
		Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A	

M-8

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/2375 dated 27/12/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature
27/8/22

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

FOT

DCFO (SZ)

Signature
AND (BCP)

As approved, f.t. letter is put up for your signature pl.

Signature
20/9/2022

Signature

Signature

MS. *Signature*

file received on 20/9/2022 fsc uploaded
Signature
20/9/22