

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022 / 1037

Dated: 20 / 9 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Girls School** located at **Nehru Vihar, Delhi-110054** comprised of **Ground & First Floor Only** owned/occupied by **M.C. Primary Girls School** was granted FSC by this department vide letter no. **F6/DFS/MS/School/2019/WZ/1657** dated **21.08.2019**. The premises was re-inspected by the officer concerned of this department on **09.09.2022** in presence of **Sh. Naveen (Guard)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from**20/9/22**.... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **20/9/22** at New Delhi by


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. Incharge, M.C. Primary Girls School located at Nehru Vihar, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate. **six months** prior to its expiry".

11/19
INSPECTION REPORT

1. Name & address of the building : M.C. Primary Girls School located at Nehru Vihar, Delhi-110054.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First Floor Only
4. Type of Case : Renewal
5. Details of previous NOC : F6 DFS/MS/School/2019/WZ/1657 dated 21.08.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 09.09.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Naveen (Guard)
10. Year of Construction : 1985-2015
11. Applicant's letter No. : Letter No. Nil Dated-06.08.2022

Plot Area-4454 sq. m2 Covered Area:1184.25 sq.m2 No. of Class Room-12 No. of Student-320

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>6m</p> <p>4.5m</p> <p>5m</p>	<p>6m</p> <p>03m</p> <p>5m</p>	<p>MR</p> <p>MR(old case)</p> <p>MR</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02</p> <p>NA</p>	<p>02</p> <p>NA</p>	<p>MR</p> <p>NA</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>1.5 m</p> <p>NA</p>	<p>1.50 each</p> <p>NA</p>	<p>MR</p> <p>NA</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1.14m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>12 a/c per hour</p> <p>12 a/c per hour</p>	<p>NA</p> <p>Natural Ventilated</p>	<p>NA</p> <p>MR</p>
5	Fire Extinguishers			

20

N/15

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	04nos ABC/Co2	04 nos ABC 04	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting, Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA

Q

MR
MR
MR

N/16

Captive Water Storage for fire fighting.

- Underground tank capacity
- Draw-off connection
- Fire service inlet
- Access to tank
- Overhead Tank capacity

NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA

Exit Signage.

Required	Provided	MR
----------	----------	----

Provision of Lifts.

- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication In lift Car
- Fireman's Grounding Switch
- Lift Signage

N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

Standby power supply

Refuge Area.

- Total Area
- Location

N/A	N/A	N/A
N/A	N/A	N/A

Fire Control Room

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Batter backup
- Building Floor Plans

N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

Special Fire Protection Systems for Protection of special Risks, if any:

N/A	N/A	N/A
-----	-----	-----

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1657 dated 21.08.2019

DO/NW
12/09/2022
By S/O (W2)

14/9/2022

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation: - ADO/RN

AS approved

AS approved, F.T. letter is put up for your signature pl.

16/09/2022