



C-30

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/EH/2022/NDZ/ 256

Dated: 14/9/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Pizza Hut (Unit of Devyani International Ltd.) located at Ground Floor, G-5A, Dilshad Garden Metro Station Delhi-95, building comprised of Ground, 1st Floor & 2nd Floor, but restaurant is running at Ground Floor only owned / occupied by A Unit of Devyani International Ltd., was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2019/NDZ/2188 dated 21/11/19. The premises was re-inspected by the officer concerned of this department on 24/08/2022 in the presence of Sh. Pravesh Kumar (Manager) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" Group-D (Restaurant) with effect from 14/9/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on14/9/22..... at New Delhi.


(S.K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE.**



Copy to :-

1. The Joint Commissioner of Police (Lic.), First Floor, Police Station Defence Colony, New Delhi-49 w.r.t. MHA Portal ID-2022081516159 dated 16/08/2022.
2. The Manager, M/S Pizza Hut (A Unit of Devyani International Ltd.)(Restaurant), Ground floor, G-5A, Dilshad Garden Metro Station, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Any Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

N/A

1. Name & address of the building: M/s Pizza Hut (Unit of Devyani International Ltd.)
Ground Floor, G-5A, Dilshad Garden Metro Station Delhi-95
2. Building is comprised of : Building is ground plus two upper floors
(Restaurant on ground floor only)
3. Type of Occupancy : Restaurant (Assembly)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2019/NDZ/2188 dated-21/11/19
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 24/08/2022
8. Name of the Inspecting Officer : Ashok Kumar Jaiswal, D.O. (East)
9. Name and designation of Officer
from the building side : Sh. Pravesh Kumar (**Manager**)
10. Year of Construction : 2008

11. Applicant's letter received through MHA portal ID-2022081516159 dated 16/08/2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirements | Provided at site | Remarks MR/NMR |
|------|---|---------------------|---------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 12mtr | 18 mtr. | MR |
| | • Gate width | 06 mtr. | 06 mtr. | MR |
| | • Width of internal road | 06 mtr. | 06 mtr. | MR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper floors | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | | | |
| | • No of continuous staircase to terrace | N/A | N/A | N/A |
| | e. Width Of Corridor | | | |
| | • Width Of Corridor | N/A | N/A | N/A |
| | f. Door Size | | | |
| | • Door Size | 02mtr | 02 mtr & 1.50mtr | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | Required | Sealed | MR |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 04 nos. | 06 nos. | MR |
| | • Types | ABC/CO ₂ | ABC/CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

(Signature)

| | | | | |
|-----|--|---------------------------|---------------|-----|
| 6. | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | 01 | 01 | MR |
| | • Length of hose reel hose | 30 Mtr. | 30 Mtr. | MR |
| | • Nozzle diameter | 5 mm | 5 mm | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | Required | Provided | MR |
| | • Location of Main Panel | N/A | Provided | N/A |
| | • Location of Repeater Panel | N/A | Provided | N/A |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Ground Floor | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100 mm | 150 mm | MR |
| | • Number of hydrants per floor | 01 nos. | 04 nos. | MR |
| | • Hose Box | 01 nos. | 04 nos. | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | 14 nos. | MR |
| | • Hose Box | N/A | 14 nos. | MR |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | Common with Metro Station | | |
| | ➤ Discharge of main pump | 450 LPM | 4500 LPM | MR |
| | ➤ Head of main pump | 80 mtr | 80 mtr | MR |
| | ➤ Number of main pumps | 01 nos. | 01 nos. | MR |
| | ➤ Jockey pump out put | 180 LPM | 180 LPM | MR |
| | ➤ Jockey pump head | 80 mtr. | 80 mtr. | MR |
| | ➤ Standby Pump out put | 450 LPM | 4500 LPM | MR |
| | ➤ Standby Pump Head | 80 mtr | 80 mtr | MR |
| | ➤ Auto Starting/Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | 20,000 Ltr. | 2,00,000 Ltr. | MR |
| | ➤ Draw of connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | N/A | N/A | N/A |

N/A

| 15 | Exit Signage | Required | Provided | MR |
|-----|--|----------|----------|-----|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | N/A | N/A | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | N/A | N/A | N/A |
| | ➤ Flow Switch Panel | N/A | N/A | N/A |
| | ➤ PA System Panel | N/A | N/A | N/A |
| | ➤ Battery backup | N/A | N/A | N/A |
| | ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A | N/A |

The Fire Protection System provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance of the minimum standards of Fire Prevention and Fire Safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2019/NDZ/2188 dated 21/11/19 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
26/08/22

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

~~Dy. CFd (NDZ)~~

F.T. please.

ADP
30/08/22

~~DO (ED)~~

F.T. is added please.

ADP
01/09/22

~~Dy. CFd (NDZ)~~

ADP
29/09/22

F.P. wing