



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/914

Dated: 26/08/2022

FIRE SAFETY CERTIFICATE

Certified that the Happy Time Public School, D-Block, Bhajanpura, Delhi-110053, building comprised of Ground + Three upper Floors only, owned / occupied by Happy Time Public School, was inspected by the officer concerned of this department on 08/08/2022 in presence of Mrs. Raj Rani (Principal) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises have complied with D.O.E. Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 26/08/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/08/2022 at New Delhi by.


(ATUL GARG)
DIRECTOR.

Copy to :-

1. The Principal, Happy Time Public School, D-Block, Bhajanpura, Delhi-110053.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

N/10

1. Name & address of the building: Happy Time Public School,
D-Block, Bhajanpura, Delhi-110053.
2. Building is comprised of : Ground, First, Second & Third floor only.
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : N/A
6. Fire Safety directives Letter No.: D.O.E. Circular No. 262-362 Dated 17/01/2005
7. Date of inspection : 08/08/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer
from the building side : Mrs. Raj Rani (Principal)
10. Year of Construction : 1988
11. Applicant's letter No. : Nil Outdoor Dairy Dated 05/08/2022

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E. Circular 2005 Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m	1.0 m & 0.90 m	MR (Existing School may be accepted as old case prior to 2010)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door size	1.0 m	1.10 m	MR
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	10 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

DA

N/11

6	First-aid-Hose Reels			
	Total numbers of each floor	01 Nos.	01 Nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13				
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	5,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage	Required	Provided	MR

N/12

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- This is Existing School and running prior to enactment of DFS Act 2007 Rule 2010 i.e. viz. from year 1988 (please see N/1 & C/13). Shortcoming which has been issued as per D.O.E. Circular Dated 17/01/2005 by this department vide letter no. F6/DFS/MS/08//2038 Dated 21/07/2008 (Please see N/1 & C/2) now rectified.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under D.O.E. Circular No. 262-362 Dated 17/01/2005.

Ashok Kumar Jaiswal
16/08/2011

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

~~By: CFO (NDZ)~~

R.P.
18/08/2011

~~C.F.O.~~
Vineet
22/08/2011

~~Director~~
[Signature]
22/08/2011

~~Director~~
[Signature]
26/08/2011

Sir,
As Approved, F.T. is added for sign. pl.

[Signature]
24/08/2011