

421

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F-6 / DFS / MS / 2022 / School / WZ / 902

Dated: 18/8/2022

FIRE SAFETY CERTIFICATE

Certified that **CL. Indian Public School** located at **Khasra No. 251, Main Road Holambi Khurd, Delhi-110082** comprised of **Ground+One upper floor** owned/occupied by **CL. Indian Public School** was issued fire safety certificate vide letter no. **F-6/DFS/MS/2019/1456** dated-**16/07/2019**. The premises was inspected by the officer concerned of this department on dated 05.08.2022 in the presence of Sh. Jawahar Singh Mann (Chairman) and found that the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 01/03/2011** and that the building / premises is fit for occupancy of **Class B (Educational)** with effect from 18/8/2022 for a period of **three years**, subject to the compliance of the conditions mentioned below.

Issued on ...18/8/2022... at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Khasra No. 251, Main Road Holambi Khurd, Delhi-110082.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. Pota Cabin (Three rooms) seen at first floor shall not used for school activity.

N-16

INSPECTION REPORT

1. Name & address of the building : CL. Indian Public School, Kh. No. 251, Main Road Holambi Khurd, Delhi-110082.
2. Type of Occupancy : Educational
3. Building Comprised : Single Block (Ground + First Floor)
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2019/1456 Dated-16/07/2019
6. Fire Safety directives letter No : Dir of Edu. Cir dated 01.03.2011.
7. Date of inspection : 05/08/2022
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers : Sh. Jawahar Singh Mann (Chairman)
- From the building side : 2008 & 2013.
10. Year of Construction : Letter No. CL. IPS/2022-23/42 , Dated-21/07/2022
11. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.27 m & 0.84 m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

AS

N-17

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilated	MR
5.	Fire Extinguishers <ul style="list-style-type: none"> Total numbers Types IS marking 	04 ABC Yes	07 ABC/Co2 Yes	MR MR MR
6.	First-Aid Hose Reels <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants <ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA

RV

MR	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	NA	NA	NA
MR	➤ Head of the pump	NA	NA	NA
MR	➤ Power Supply	NA	NA	NA
MR		-	-	-
	➤ Auto Starting of pump	NA	NA	NA
NA	14. Captive Water Storage for fire fighting			
NA	• Underground tank capacity	NA	NA	NA
NA	➤ Draw-off connection	NA	NA	NA
NA	➤ Fire service inlet	NA	NA	NA
NA	➤ Access to tank	NA	NA	NA
NA	• Overhead Tank capacity	NA	NA	NA
NA		NA	NA	NA
NA	15. Exit Signage.	NA	NA	NA
	16. Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
		NA	NA	NA
	17. Standby power supply	NA	NA	NA
	18. Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
	19. Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
	20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

M

--	--	--	--	--

Previously school building was comprised of two blocks Ground Floor & Ground+one upper floor but now management had demolished one block of Ground Floor.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/2019/1456.

Do (w/c)

08/08/2020

Dy CPO (w2)

12/8/2022

ADO/B.W. F-T letter in para for sign please

Dy CPO (w2)

12/8/2022

rust cell

ADO (B.W.)
8/8/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

ADO (B.W.)
12/8/22