



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**


No. F6/DFS/MS/School/2022/NDZ/ 1065

Dated: 23/9/22

**FIRE SAFETY CERTIFICATE**

Certified that the National Victor Public School at C-Block, DDA Colony, West Gorakh Park, Shahdara, Delhi-110032, comprised of basement, ground plus one upper floor, owned/occupied by National Victor Public School was issued FSC vide letter No. F.6/DFS/MS/School/2019/NDZ/526 dated 14/03/19. The premises was re-inspected by the officer concerned of this department on 12/09/2022 in the presence of Mr. Sharvan Kumar (Admin.) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 23/9/22 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on .....23/9/22..... at New Delhi by



(S.K. DUA)

**DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE**

dk 2

To,

The Principal,  
National Victor Public School,  
C-Block, DDA Colony, West Gorakh Park, Shahdara, Delhi- 110032

Copy:-

The Director of Education,  
B-Block Yamuna Vihar, Delhi-110053

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

- N/V/S
1. Name & address of the building : National Victor Public School  
C-Block, DDA Colony, West Gorakh Park,  
Shahdara, Delhi-110032
  2. Building is comprised of : Basement, Ground plus one upper floor only
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of Previous NOC letter : F.6/DFS/MS/School/2019/NDZ/526 dated 14/03/19
  6. Fire Safety direction letter No : Circular No. 262-362 dated 17/01/2005 issued by DoE
  7. Date of Inspection : 12/09/2022
  8. Name of the Inspecting officers : ADO (Shd.)
  9. Name and designation of Officer  
from the building side : Mr. Sharvan Kumar (Admin.).
  10. Year of Construction : 2003-2004
  11. Applicant's letter No : Email nationalvictor2005 dated 01/09/2022

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	DoE Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 mtrs N/A N/A	06 mtr. ✓ N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	01 nos. 02 nos.	01 nos. ✓ 02 nos.	MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	1.50 mtr 1.25 mtr	1.55 mtr 1.50 mtr & 0.80 mtr ✓	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A

[Signature]

11/11/16

05.	Fire Extinguishers			
	• Total numbers	06 nos.	06 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	Provided	N/A
09	Public address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose Box	01 No.	01 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR



N/17

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	MR
	• Overhead Tank capacity	5,000 Ltr Required	10,000 Ltr Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings issued vide letter No. F6/DFS/MS/School/2020/NDZ/289 dated 06/06/2022 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F6/DFS/MS/School/2019/NDZ/526 dated 14/03/19 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak  
14/09/2022

Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O. (Shd)

D.O. (G.D.)

Agreed  
16/09/2022

Dy. CTO (NDZ)

F.T. please.

14/09/22

ADO (Shd.)