

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/School/2022/NDZ/ 1064

Dated: 23/8/22

FIRE SAFETY CERTIFICATE

Certified that the Uma Devi Public School located at 1/7412, Shiv Marg, Shivaji Park, Delhi-110032, comprised of ground plus two upper floor, owned/occupied by Uma Devi Public School has already been issued FSC vide letter no. F6/DFS/MS/School/2019/NDZ/989 dated 10/05/2019. The premises was re-inspected by the officer concerned of fire service on 02/08/2022 in the presence of Mrs. Kamlesh Sharma, H.M. of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 23/8/22 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 23/8/22 at New Delhi by


(S.K. DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To,

The Head Mistress
M/s Uma Devi Public School
1/7412, Shiv Marg, Shivaji Park, Delhi-110032

Copy:-

The Dy. Director of Education,
B- Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

expiry

N/5

1. Name & address of the building : Uma Devi Public School,
1/7412, Shiv Marg, Shivaji Park, Delhi-110032
2. Building is comprised of : Ground plus two upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter No. : F6/DFS/MS/School/2019/NDZ/989 dt 10/05/2019
6. Fire Safety directive letter No. : NBC Part IV
7. Date of Inspection : 02/09/2022 ²
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer
from the building side : Mrs. Kamlesh Sharma, H.M.
10. Year of Construction : 1984
11. Applicant's letter No : UDPS/22 dated 21/07/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks
01	Access to Building			MR/NMR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	01 no. N/A	02 no. ✓ N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.50 mtr N/A	1.00 mtr & 0.85 mtr N/A	MR (old Accepted) N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr ✓	MR
	f. Door Size	1.00 mtr.	1.00 mtr. ✓	MR
03	Compartmentation.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos. ABC /CO ₂ ISI marked	06 nos. ✓ ABC /CO ₂ ISI marked	MR MR MR

2

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR ✓
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm ✓	MR ✓
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltr	10,000 Ltr	MR ✓
15	Exit Signage.	Required	Provided	MR

2. *[Signature]*

N/7.

16	Provision of Lifts			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No. F6/DFS/MS/School/2019/NDZ/989 dated 10/05/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
06/09/2022
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

~~DO(ED)~~ DFA RL.

AKB
07/09/2022
Dx. CFQ(NDZ) - Date of inspection is shown - 02/08/2022
Date of submission of Insp report - 06/09/2022
Reason of delay?

AKB
09/09/2022
AKB
08/09/22

~~DO(ED)~~ ADD/shd. Sir, It will be taken care in future. Delay is regretted.
Deepak
09/09/2022