

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No. F.6/DFS/MS/CNG/2022/SZ/ 432

Dated: 28/09/2022

FIRE SAFETY CERTIFICATE

Certified that the **CNG Station** at Khasra No. 5/23/1, Village- Kharkhari Nahar, Tehsil Najafgarh, Delhi-110043, comprised of ground floor only, (03 Dispenser with 06 points) owned/occupied by **M/s Indraprastha Gas Limited**. The premises were inspected by the officer concerned of this department on 15/09/2022 in the presence of Sh. Vikram Yadav (Manager) and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**CNG Dispensing Station**) is fit for occupancy Class "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....28/09/2022.....at New Delhi.


(A. V. T. SARGI)
DIRECTOR
DELHI FIRE SERVICE
9/9/22

Copy to:-

1. The Vice-President (F&S),
Indraprastha Gas Limited, IGL Bhawan, Plot No.-4,
Community Centre, Sector-9, R.K.Puram, New Delhi-110022
2. The Joint C.P. (I.c.),
Police Station, Defence Colony, New Delhi

Following fire safety directives must be adhered to

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: CNG Station at khasra No. 5/23/1, Village- Kharkhari Nahar, Tehsil Najafgarh, Delhi-110043
2. Type of Occupancy : Group "F" Hazardous (CNG Facility)
3. Building comprised of : Ground floor only.
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 15/09/2022
8. Name of Inspecting Officer : ADO R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Vikram Yadav (Manager)
10. Year of Construction : 2020-21
11. Applicant's letter No. : IGI./CNGPRJ/NOC/17062022 dated 10/06/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>12 m</p> <p>NA</p> <p>NA</p>	<p>45 m Provided</p> <p>Directly accessible from road</p> <p>NA</p>	<p>MR</p> <p>NA</p> <p>NA</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<p>12 Nos.</p> <p>Required</p> <p>ISI</p>	<p>Provided</p> <p>6 Nos. DCP Type (3 kg). 4 Nos. CO2 Type 4.5 kg. 2 Nos. DCP Type (75 kg) trolley mounted</p> <p>Provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>

A

First-Aid Hose Reels

• Total numbers on each floor	NA	NA	NA
• Length of hose reel hose	NA	NA	NA
• Nozzle diameter	NA	NA	NA

Automatic fire detection and alarming system

• Gas and flame detectors	Required	Provided	MR
• Location of Main Panel	Required	Office at GF	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	Required	Provided	MR
• Hooters' Location	Required	At station	MR

MOEFA

Required	Provided	MR
----------	----------	----

Public Address System

Required	Provided	MR
----------	----------	----

Automatic Sprinkler System

• Basement	NA	NA	NA
• Ground Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA

Internal Hydrants

• Size of riser/down-comer	NA	NA	NA
• Number of hydrants per floor	NA	NA	NA
• Hose Box	NA	NA	NA

Yard Hydrants

• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA

Pumping Arrangements

• Ground Level	NA	NA	NA
➤ Discharge of main Pump	NA	NA	NA
➤ Head of Main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey Pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Starting/Manual Stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace level	NA	NA	NA
➤ Discharge of pump	NA	NA	NA
➤ Head of the pump	NA	NA	NA
➤ Power Supply	NA	NA	NA
➤ Auto Starting of pump	NA	NA	NA

Captive Water Storage for fire fighting

• Underground tank capacity	NA	NA	NA
➤ Draw-off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA

No Smoking Signage.

Required	Provided in Hindi & English	MR
----------	-----------------------------	----

16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	Provided (DG Set)	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Provided	MR


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 (3) of the Delhi Fire Service Rules 2010.










Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.

Two hand held explosive meters are also provided.


 Signature of Inspecting Officer
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

D.O (South West)

 20/9/22
 (S2)

 (FO)
 21/9/2022
 Director 22/9/22
 D.O/SW
 20/9/22
 Add (Inspector)