




No. F6/DFS/MS/School/WZ/2022/ 1086

Dated: 29/9/2022

FIRE SAFETY CERTIFICATE

Certified that the **D. S. Memorial Public Sr. Sec. School** Located at **Extension, 2-C, Nangloi, Delhi-110041**, comprised of Block-I = Basement + Ground + 02 Upper Floor & Block-II = Ground + 02 Upper Floor owned / occupied by D. S. Memorial Public Sr. Sec. School, was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/WZ/2019/1551** dated **30.07.2019**. The said premise was re-inspected by the officer concerned of this department on 13.09.2022 in the presence of Sh. Mahipal Yadav, (Owner) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01.03.2011 / NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 28/9/22 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on 28/9/22 ... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, D. S. Memorial Public Sr. Sec. School, Extension, 2-C, Nangloi, Delhi-110041

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

INSPECTION REPORT

N-15

1. Name and address of the building: **D.S. Memorial Public Sr. Sec. School** Located at **Extension, 2-C, Nangloi, Delhi-110041.**
2. Type of Occupancy : Educational, Block-I=Basement+Ground+02 Upper floor & Block-II=Ground+02 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2019/1551 Dated 30.07.2019
5. Fire Safety directives Letter No. : Cr. No. 3298-3398 dated 01-03-2011/NBC (Part-IV)
6. Date of inspection : 13.09.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Mahipal Yadav, (Owner)
9. Year of Construction : 2006-07 (G+2), 2012-13 (B+G+2)
10. Applicant's letter No. : DSM/2022/1555 dated 14.07.2022

S/No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 30.07.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-I (for B+G+2)* BL-II (for G+2)	1* 2	MR (After 2010)*
	• Basements	1.5 m	1.5 x 2	MR
	b. Width of staircases			
	• Upper floors	1.5 m	1.5 m x 1 in BL-I* 1.6 x 1, 1.5 m x 2 in BL-II	MR (After 2010)*
	• Basements	1.5 m	1.5 m x 2	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

①

14-16

IS
16
Ex
Pro

5.	Fire Extinguishers	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 nos.	20 nos.	MR
			ABC & CO ₂	Provided	MR
			ISI marked	Provided	MR
6.	First - Aid Hose Reels	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	BL-I=1	Provided	MR
			BL-II=2		
			30 m	Provided	MR
			5 mm	Provided	MR
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
NA		NA	NA	NA	
8.	MOEFA		NA	NA	NA
9.	Public Address System		NA	NA	NA
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR	
		NA	NA	NA	
NA		NA	NA		
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	Required (Old Block of G+2)	100 mm	MR	
		Required (Old Block of G+2)	01	MR	
Required (Old Block of G+2)		01	MR		
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA	
			NA	NA	NA
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		900 lpm for B+G+2 Block	Provided	MR	
	450 lpm & 180 lpm for G+2 Block				
45 m	Provided	MR			
Required	Provided	MR			
Required	Provided	MR			
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA	
		NA	NA	NA	
		Required (Old Block of G+2)	Provided	MR	
		NA	NA	NA	
15,000 ltrs in B+G+2 & 5,000 ltrs in G+2 (Old block)		Provided	MR		

Handwritten signature

M-17

		Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2019/1551 Dated 30.07.2019 is recommended.

Accordingly DFA is put up for approval please.

Amit
20/09/22
Aman Kumar Lathar
ADO (JWP)

D.O. (WEST) 387
DATED 20/09/22

~~D.O. (W)~~
~~20/09/22~~
~~D.O. (W2)~~
~~21/9/22~~

~~D.O. (W)~~
F.F. letter is put-up for signature Mr.

~~D.O. (W2)~~
~~21/9/22~~

Amal
22/09/22
ADO (JWP)

MSY *AM*