

C-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2022/ School/WZ/ 1092

Dated: 29/9/22

FIRE SAFETY CERTIFICATE

Certified that **Jawahar Navodaya Vidyalaya** located at **Mungeshpur, Delhi-110039** comprised of **Ground+One upper floor** owned/occupied by **Jawahar Navodaya Vidyalaya** was issued fire safety certificate vide letter no. **F-6/DFS/MS/School/2011/2884 dated-04/11/2011**. The premises was inspected by the officer concerned of this department on dated 22.09.2022 in the presence of Sh. Surjit Singh (Principal) and found that the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 01/03/2011** and that the building / premises is fit for occupancy of **Class B (Educational)** with effect from 29/9/22 for a period of **three years**, subject to the compliance of the conditions mentioned below.

Issued on 29/9/22 at New Delhi


 (Dharampal Bhardwaj)
 Dy. Chief Fire Officer
 West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Jawahar Navodaya Vidyalaya, Mungeshpur, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Jawahar Navodaya Vidyalaya, Mungeshpur, Delhi-110039.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + First Floor
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2011/288 Dated-04/11/2011
6. Fire Safety directives letter No : Dir of Edu, Cir dated 01.03.2011.
7. Date of inspection : 22/09/2022
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Sh. Surjit Singh (Principal)
10. Year of Construction : 1992 & 2000
11. Applicant's letter No. : Nil, Dated-06/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> Road width Gate width Width of internal road 	6.0 m 4.5 m NA	6.0 m 4.5 m NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits <ol style="list-style-type: none"> Number of staircases <ul style="list-style-type: none"> Upper Floors Basements Width of staircases <ul style="list-style-type: none"> Upper Floor Basements Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization No. of continuous staircases to terrace Width of Corridor Door Size 	02 NA 1.50 m & 75 cm NA NA NA NA NA NA NA NA 1.00 m	03 NA 1.95 m & 1.30 m NA NA NA NA 02 2 m Provided	MR NA MR NA NA NA NA NA NA NA MR
3.	Compartmentation <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System <ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA

4

- Upper floors

12 a/c per hour

Natural
Ventilated

MR

5. **Fire Extinguishers**
- Total numbers
 - Types
 - IS marking
6. **First-Aid Hose Reels**
- Total numbers on each floor
 - Length of hose reel hose
 - Nozzle diameter
7. **Automatic fire detection and alarming system**
- Type of detectors
 - Location of Main Panel
 - Location of Repeater Panel
 - Alternate source of power
 - Hooters' Location

10

ABC

Yes

NA

NA

NA

NA

NA

NA

NA

NA

NA

Required

23

ABC Co2

Yes

NA

NA

NA

NA

NA

NA

NA

NA

NA

Provided

MR

MR

MR

NA

NA

NA

NA

NA

NA

NA

NA

NA

MR

- Basement
- Ground Floor
- Sprinkler above false ceiling

NA

NA

NA

NA

NA

NA

NA

NA

NA

Internal Hydrants

- Size of riser/down-comer
- Number of hydrants per floor
- Hose Box

NA

NA

NA

NA

NA

NA

NA

NA

NA

Yard Hydrants

- Total number of hydrants
- Hose Box

NA

NA

NA

NA

NA

NA

Pumping Arrangements

- Ground Level
 - Discharge of main Pump
 - Head of Main pump
 - Number of main pumps
 - Jockey Pump out put
 - Jockey pump head
 - Standby Pump out put
 - Standby Pump Head
- Auto Starting/Manual Stopping

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

92

MR	➤ Pump House Access	NA	NA	NA
MR	• Terrace level	NA	NA	NA
MR	➤ Discharge of pump	NA	NA	NA
R	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
		NA	NA	NA
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

12

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/School/2011/2884.

~~DO (H)~~ on goff

~~DO (H)~~ (102)

~~DO (H)~~ 26/9/22

~~DO (H)~~ 23/9/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~ADO/B.W.~~ F-T letter in putp for signature

~~ADO/B.W.~~ 26/9/22

~~DO (H)~~ (102)

~~DO (H)~~ 27/9/22

MS/ cell