

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

C-19

No.F.6/DFS/MS/School/2022/SZ/ 1079

Dated: 28/9/22

**FIRE SAFETY CERTIFICATE**

Certified that the Mata Kaushlaya Public School, Plot No.22-23, Tara Nagar, Kakrola Road, New Delhi-110043, comprised of ground plus one upper floor, having total 12 rooms (Including Class rooms, office & store etc.) owned/occupied by Mata Kaushlaya Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2018/SZ/1429 dated 19/06/2018. The School building was re- inspected by the officer concerned of this department on 21/09/2022 in the presence of Smt. Sudesh Thakur and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.262-362 dated 17/01/2005 issued by the Director of Education, Govt. of NCT of Delhi and that the building/ premises is fit for occupancy class 'Educational' w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....28/9/22..... at New Delhi.

(SUNIL CHAUDHARY)  
DY.CHIEF FIRE OFFICER

*Sey*

Copy to:-

1. The Manager,  
Mata Kaushlaya Public School,  
Plot No.22-23, Tara Nagar, Kakrola Road, New Delhi-110043.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/11

**INSPECTION REPORT**

- Name & address of the building : Mata Kaushlaya Public School, Plot No.22-23, Tara Nagar, Kakrola Road, New Delhi-110043.
2. Building is comprised of : Ground plus one upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal.
5. Details of Previous NOC : F.6/DFS/MS/School/2018/SZ/1429 dated 19/06/2018.
6. Fire Safety directives letter No : N/A
7. Date of inspection : 21/09/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Smt. Sudesh Thakur
10. Year of Construction : Before 2006
11. Applicant's letter No. : Letter No. Nil dated 12/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 17.01.2005/ Letter dt. 4.12.2006	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 m 4.5 m N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 No's N/A	02 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.50 m & .75 m N/A	1.08 & 1.06 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		1.5 m	1.42 m	M/R
	f. Door Size			
		1.0 m	.89 m	M/R, being Old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	N/A Required	N/A Natural Ventilation	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	04 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	M/R M/R M/R

10


N/A

6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	<b>Exit Signage.</b>	Required	Provided	MR




Division of Lifts.		No Lift		
N/A	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
N/A		N/A	N/A	N/A
N/A		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Battery backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/School/2018/SZ/1429 dated 19/06/2018 renewal under the Circular dated 17/01/2005 (DOE) is recommended.

  
 Signature of Inspecting Officer  
 Name:- R.K.Yadav  
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

  
  
  
 M.S. Cell A.D. (S2)  
 FT letter & put up for sign please  
