

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/ 1088

Dated: 28/9/22

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi-110027**, Comprised of ground plus two upper floors (A- Block), owned/occupied by Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 15/09/2022 in the presence of Sh. Jeet (Estate Manager) and found that the school building (**A Block only**) is fit for occupancy class B 'Educational Building' for with effect from 28/9/22 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....28/9/22.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. **This NOC is valid for A- block only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Rajouri Garden Main, New Delhi-27
2. Building comprised of : **3 blocks (A block G+2, B block G+1 declared dangers by PWD d & C block G+3 already issued FSC)**
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 15/09/2022
8. Name of Inspecting Officer : A.D.O.R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Jeet (Estate Manager)
10. Year of Construction : 1956 & before
11. Applicant's letter No. : Nil dated 10/08/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible	09 mtrs 3.8 & 7.5 mtrs	M/R
2.	Number, Width, Type & Arrangement of Exits <p>a. Number of staircases</p> <ul style="list-style-type: none"> Upper Floors Basements <p>b. Width of staircases</p> <ul style="list-style-type: none"> Upper Floor Basements <p>c. Protection of exits</p> <ul style="list-style-type: none"> Fire check door Pressurization <p>d. No. of continuous staircases to terrace</p> <p>e. Width of Corridor</p> <p>f. Door Size</p>	02 No's in A Blk. N/A	02 No's in A Blk N/A	M/R N/A
		1.5 m each N/A	1.60 m each N/A	M/R N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	One	N/A
		1.5 m	3.15 m in A Blk	M/R
		1.0 m	1.05 m (Double doors)	M/R
3.	Compartmentation <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System <ul style="list-style-type: none"> Basements Upper floors 	N/A	N/A	N/A
		N/A	Natural ventilation	N/A
5.	Fire Extinguishers <ul style="list-style-type: none"> Total numbers Types IS marking 	45 no's ABC/CO2 type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels (A Block) <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

N/15

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100 mm	MR
	• Number of hydrants per floor	N/A	Two	MR
	• Hose Box	N/A	Two	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	M/R
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			

N/LG

Total Area	N/A	N/A	N/A
Location	N/A	N/A	N/A
Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety as required under the Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

[This FSC is for A Block only G+2]

Signature of Inspecting Officer
 Name :- R.K. Yadav
 Designation:- Asstt. Divisional Officer

D.O. (South West)

als
 20/9/22
 F.T.
 Dy C.O. (SW)
 C.F.O. 22/9/2022
 Director
 27/9/22
 ADO 30/9/22
 Dy SW 26/9