

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F-6/DFS/MS/SZ/2022/ EH/437

Dated: 30/09/2022

FIRE SAFETY CERTIFICATE

Certified that the Laidback Café A Unit of Burgeon Enterprises Located at Unit No. R 04B 5th Floor Plot No. 6 Sector-14, Vegas Mall Dwarka New Delhi-110078, in a building comprised of 4 Basement + Ground + 05 Upper Floors Fire Safety Certificate issued to mall vide letter No F6/DFS/MS/Mercantile/2019/SZ/1972 dated 16/10/19 owned/ occupied by **Laidback Cafe** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 21/09/2022 in the presence of Mr. Asit Sharma (Corporate Head) Mr. Rohit Sharma (Manager) and found that the said building is fit for occupancy class " Assembly" Group D with effect from 30/09/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/09/2022 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, Laidback Café A Unit of Burgeon Enterprises Located at Unit No. R 04B 5th Floor Plot No. 6 Sector-14, Vegas Mall Dwarka New Delhi-110078.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Laidback Café A Unit of Burgeon Enterprises Located at Unit No. R 04H 5th Floor Plot No. 6 Sector 14, Vegas Mall Dwarka New Delhi-110078.
2. Type of Occupancy : Class-D (Assembly) **(At 5th Floor in the Mall)**
3. Type of Case : New
4. Details of previous NOC: F6/DFS/MS/Mercantile/2019/SZ/1972 dated 16/10/19 **(issued to mall)**
5. Fire Safety directives Letter No. : F6/DFS/MS/HP/2016/326 Dated 16/12/2016 **(issued to mall)**
6. Date of inspection : 21/09/2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Asit Sharma (Corporate Head) &
Mr. Rohit Sharma (Manager)
9. Year of Construction : 2022
10. Applicant's letter No. : 2022090216983 Dated-05/09/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBI/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 mtrs 06mtr 06 mtr	Provided Provided Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases	3	03 Provided (by Mall)	MR
	<ul style="list-style-type: none"> Upper floors Basements 	NA	12 Provided by Mall	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	1.5 mtr NA	Provided by Mall Provided	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2m & 1.5 M	2 X 2 mtr	MR
3.	Compartmentation(Common With Mall)			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	Provided by Mall Provided by Mall Provided by Mall Provided by Mall Provided by Mall	NA NA NA NA NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	• Total numbers	03 nos. each type	Provided	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	• Total numbers on each floor	Required	Provided by Mall	MR
	• Length of hose reel hose	36 m	Provided by Mall	MR
	• Nozzle diameter	5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System (Common with mall)			
	• Basements	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants: (common with the mall)			
	• Size of riser/down- comer	150 mm	Provided by Mall	MR
	• Number of hydrants per floor	1	3 Provided by Mall	MR
	• Hose Box	Required	Provided by Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided by Mall	NA
	• Hose Box	NA	Provided by Mall	NA
13.	Pumping Arrangements: Common with Mall			
	• Ground Level			
	• Discharge of main pump	2850 lpm	Provided By Mall	MR
	➤ Head of main pump	120 m	Provided By Mall	MR
	➤ Number of main pumps	02	Provided By Mall	MR
	➤ Jockey pump out put	180 LPM 2 Nos+Water Curtain Pump 2280 LPM	Provided By Mall	MR
	➤ Jockey pump head	120 m	Provided By Mall	MR
	➤ Standby Pump out put	2850 lpm	Provided By Mall	MR
	➤ Standby Pump Head	120 m	Provided By Mall	MR
	➤ Auto Staring/Manual stopping	Required	Provided By Mall	MR
	➤ Pump House Access	Required	Provided By Mall	MR
	• Terrace level			
	➤ Discharge of pump	900lpm	Provided By Mall	MR
	➤ Head of the pump	40 m	Provided By Mall	MR
	➤ Power supply	Required	Provided By Mall	MR
	➤ Auto starting of pump	Required	Provided By Mall	MR

15
16

20

N13

14.	Captive water Storage for fire fighting: Common with Mall		
	• Under ground tank capacity	NA	400000 l (By Mall) NA
	➤ Draw off connection	NA	Provided By Mall NA
	➤ Fire service inlet	NA	Provided By Mall NA
	➤ Access to tank	NA	Provided By Mall NA
	• Overhead Tank capacity	20, 000 litres	Provided By Mall MR
15.	Exit Signage	Required	Provided By Mall MR
16.	Provision of Lifts Common with Mall		
	➤ Pressurization of Lift Shaft	NA	Provided By Mall NA
	➤ Pressurization of lift lobby	NA	Provided By Mall NA
	➤ Communication in lift Car	NA	Provided By Mall NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall NA
	➤ Lift Signage	NA	Provided By Mall NA
17.	Standby power supply	Required	Provided By Mall MR
18.	Refuge Area		
	➤ Total area	NA	Provided NA
	➤ Location	NA	Provided NA
19.	Fire control room (Common with Mall)		
	➤ Detector system panel	NA	Provided By Mall NA
	➤ Flow Switch Panel	NA	Provided By Mall NA
	➤ PA System Panel	NA	Provided By Mall NA
	➤ Battery backup	NA	Provided By Mall NA
	➤ Building Floor Plans	NA	Provided By Mall NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010

Note-

1. Laidback Café A Unit of Burgeon Enterprises Located at Unit No. R 04B 5th Floor Plot No. 6 Sector-14, Vegas Mall Dwarka New Delhi-110078.
2. As per plan submitted by the applicant the area of the restaurant is 151 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 84 (151/1.8=83.88 say 84) for whole restaurant.
4. The total seating capacity comes out be 84.

Signature of the Inspecting Officer

Name

Designation

Uday Vir Singh
ADDO/DWTK

(Signature) 22/9/22
(Signature) 22/9/22
(Signature) 22/9/22