



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Audi./2022/SZ/ 441

Dated: 30/09/2022

FIRE SAFETY CERTIFICATE

Certified that **Main Auditorium & Mini Auditorium 1 & II**, located at Baha'i House of Worship Lotus Temple Road, Bahapur, Kalkaji, New Delhi- 110019 comprised of Ground Floor only was issued FSC by this department vide letter no. F6/DFS/MS/Audi/SZ/2019/1633 dated 19/08/2019. The premise was re-inspected by the officer concerned of this department on 19.09.2022 in the presence of Mr. Jayprakash Ambrale (Service Manager) and found that the said Auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **(03 Auditorium, Seating Capacity, Main Audi 408, Mini Audi-1 & II- 70 each) occupancy Group "D" Assembly Building (Auditorium)** with effect 30/09/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 30/09/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. Baha'i House of Worship Lotus Temple Road, Bahapur, Kalkaji, New Delhi- 110019.
2. The Joint commissioner of Police, Lic/Branch, PS Defence Colony, New Delhi 110049.

Conditions for the validity of fire safety certificate:

1. The owner/occupier shall occupy the auditorium only after issue of license by the Dy. Commissioner of concerned revenue District of NCT of Delhi as notified by revenue department, Govt. of NCT of Delhi vide Delhi Gazette notification dated 09/01/2015.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

N/89

INSPECTION REPORT

1. Name & address of the building : Main Auditorium & Mini Auditorium 1 & II, Baha'i House of Worship Lotus Temple Road, Bahapur, Kalkaji, Delhi- 110019
2. Type of Occupancy : **Group "D" Assembly Building**
3. Type of Case : Renewal
4. Comprised of : Ground Floor only, (03 Auditorium, Seating Capacity, Main Audi 408m Mini Audi-1 & II- 70 each)
5. Details of Previous NOC : F6/DFS/MS/Audi/SZ/2019/1633 dated 19/08/2019
6. Fire Safety directives letter No : F6/DFS/MS/BP/92/1744-B dated 24/09/1992.
7. Date of inspection : 19/09/2022
8. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
9. Name and designation of officers from the building side : Mr. Jayprakash Ambrale (Service Manager)
10. Year of Construction : 1994
11. Applicant's letter No. : outdoor diary no 4489 dated 17/08/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required Required Required	12 m Provided Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2m	6 nos in main audi & 2 nos each in mini Audi's	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 ACPH 12 ACPH	-NA- Provided	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	16 No's ABC/W.CO ₂ /CO ₂ Required	Provided 6/5/5 Provided	MR MR MR
6.	First-Aid Hose Reels			
	Total numbers on each floor Length of hose reel hose Nozzle diameter	02 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR

1140



MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required -NA-	Ground Floor	MR
8.	MOEFA	Required	-NA-	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Required	All Floors	MR
			Provided	MR
	<ul style="list-style-type: none"> Basement Ground & Above Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		Required	Provided	MR
11.	Internal Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150mm	Provided	MR
		02 Nos	Provided	MR
12.	Yard Hydrants	02 Nos	Provided	MR
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump house access 	1620 LPM	Provided	MR
		55m	Provided	MR
		02 Nos	Provided	MR
		180 LPM	Provided	MR
		55 m	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Lts.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided (DG)	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	Required	Provided	MR
		-NA-	-NA-	-NA-

2/41



20.

<ul style="list-style-type: none">PA System PanelBattery backupBuilding Floor Plans Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Audi/SZ/2019/1633 dated 19/08/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

F.T.

Dy. CFO (SZ)

[Signature]

[Signature]

ADO (P)

As approved, F.T. letter is for backup for your signature pl

1/14/29/19

Dy. CFO (SZ)

[Signature]

M.S. UN