

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6 / DFS / MS / School / 2022 / SZ / 1097

Dated: 30/9/2022

FIRE SAFETY CERTIFICATE

Certified that **Vasant Valley School** at **Sector-C, Vasant Kunj, New Delhi-110070** comprised of ground plus two upper floors (02 Blocks), owned/occupied by Vasant Valley School was issued FSC by this department vide letter No. F.6/MS/DFS/School/2019/SZ/1201 dated 06/06/2019. The premise was re-inspected by officer concern of this department on 20/09/2022 in presence of Mr. T. Binu Alex (Admin Officer) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Educational"** Group-B with effect from 30/9/2022 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/9/22 at New Delhi by

(SUNIL CHAUDHARY)

DI. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Authorized Signatory, Vasant Valley School, Sector-C, Vasant Kunj, New Delhi-70
2. The Dy. Director of Education (South), Directorate of Education (South District), Govt. of NCT of Delhi, Sector-3, R.K Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Vasant Valley School at Sector-C, Vasant Kunj, New Delhi - 110070		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 02 upper floors (02 Blocks)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/School/2019/SZ/1201 dated 06-06-2019		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/95/765 dated 15-06-1995		
7	Date of Inspection	20-09-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. T. Binu Alex (Admn Officer)		
10	Year of construction	1998		
11	Applicant letter No.	Outdoor Diary No. 4491 dated 28-02-2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Jr. Blk=02 + 1 ramp Sr. Blk=03 + 1 ramp	Provided	MR
	➤ Basement floor.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.90m	Jr. Blk= 1.5, 1.5 & 1.9m ramp Bk=1.35, 1.35, 1.5 + 1.25m ramp	MR
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	Required	02 Nos each block	MR
	e) Width of corridor	NA	NA	NA
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4	Smoke Management system.			
	• Basement	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NA	NA
5	Fire Extinguishers.			
	• Total numbers	24 Nos	44 Nos	MR
	• Types	ABC / CO2	ABC, CO2 & W.CO2	MR
	• ISI Marking	ISI mark	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	05 Nos each	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-

8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13	Pumping arrangements.			
	• Ground Level			
	➢ Discharge of main pump.	NA	NA	NA
	➢ Head of main pump.	NA	NA	NA
	➢ Number of main pumps.	NA	NA	NA
	➢ Jockey Pump output.	NA	NA	NA
	➢ Jockey Pump head.	NA	NA	NA
	➢ Standby Pump output.	NA	NA	NA
	➢ Standby Pump head.	NA	NA	NA
	➢ Auto Starting/Manual Stopping.	NA	NA	NA
	➢ Pump house access.	NA	NA	NA
	• Terrace Level			
	➢ Discharge of pump.	280 LPM each	Provided	MR
		30 mtr	Provided	MR
	➢ Head of pump.	Required	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	NA	NA	NA
	➢ Draw-off connection.	NA	NA	NA
	➢ Fire Service Inlet.	NA	NA	NA
	➢ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	5,000 Ltr each blk.	20,000 Ltr in each	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

N/14

Vasant Valley School at Sector-C, Vasant Kunj, New Delhi-110070

The fire protection system provided in the building/premise were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/MS/DFS/School/2019/SZ/1201 dated 06/06/2019., renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

14
23/9/2022

Signature of Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

F.T.

[Signature]

ADO (BCP)

As approved, F.T. letter is put up for
your signature pl

14
26/9

F.T.

De CFO/SZ

[Signature]

MS. cell