



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2022/NDZ/ 281

Dated: 04/10/2022

FIRE SAFETY CERTIFICATE

Certified that the, M/s D S Dosa Factory Pvt. Ltd., C-210, Jhilmil Colony, Shahdara, Delhi-110095, Building comprised of Basement, Ground & Two upper Floors, but **Eating House is running on Ground Floor** only, owned / occupied by D S Dosa Factory Pvt. Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 05/09/2022 in the presence of Sh. Shivang Bhardwaj and found that the building / premises is fit for the occupancy class "Assembly" (Group-D) / **Eating House** with effect from 04/10/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/10/2022 at New Delhi by.


(ATUL GARG)
DIRECTOR.

Copy to :-

1. Joint Commissioner of Police (Lic), 1st Floor, Police Station, Defence Colony, New Delhi-110024 with reference to w r t MHA Portal id 2022043008988 dated 20/08/2022.
2. Authorised Signatory M/s D S Dosa Factory Pvt. Ltd., C-210, Jhilmil Colony, Shahdara, Delhi-110095.

Conditions for the validity of Fire Safety Certificate:

1. **This NOC is valid for ground floor only.**
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: D S Dosa Factory Pvt. Ltd.,
C-210, Jhilmil Colony, Shahdara, Delhi-110095.
2. Building is comprised of : Basement (vacant), Ground (Eating House)& Two
upper floor (Residence).
(Restaurant is running on ground floor only.)
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : New
5. Details of previous NOC No. : Nil
6. Fire Safety directives Letter No.: NBC Part-IV
7. Date of inspection : 30/08/2022
8. Name of the Inspecting Officer : D.O. (East)
9. Name and designation of Officer
from the building side : Sh. Shivang Bhardwaj
10. Year of Construction : 2002
11. Applicant's letter no. : MHA Portal id no. 2022043008988 dated 20/08/2022

S. No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part -IV Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	15 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	NA	NA	NA
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	1.50 mtr	2.00 mtr & 1.60 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	02	06	MR
	• Types	ABC /Co ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR



14/2

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power supply	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 Ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR

N/A

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	

The fire protection system provided in the building viz Fire Extinguisher were tested. checked and found functional at the time of inspection.

Keeping in view the non compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant Fire Safety Certificate under the rule 35 of Delhi Fire Service Rules 2010.

Ashok Kumar Jaiswal
 5/9/2022
 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : Divisional Officer (East)

~~DY. CFO (ADZ)~~

- This is a new case.
- Inspection shall be carried out alongwith ADD (Shah.).

Ring
 07/09/22

~~DO (ED)~~

- I - Area pertains to Adol Talispur
- II - Adol Shabd. is already overburden.

~~Dy. CFO (ADZ)~~

Ring
 12/09/22

Ashok Kumar Jaiswal
 09/09/2022

c.f.o.
Vijay
 11/09/2022
 Director
Vijay
 13/09/22

Officer
 P.T.O.