

C-61

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2022/WZ/School/ 1108

Dated: 7/10/22

FIRE SAFETY CERTIFICATE

Certified that the **St. Giri Senior Secondary School, Pocket, 25/27, Sector-III, Rohini, Delhi-110085**, comprised of **02 Blocks, Ground floor & Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/1757 dated 27.07.2018**. The premises was re-inspected by the officer concerned of this department on **21.09.2022** in the presence of **Mrs. Sanyogita Giri (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational 'Group B'** with effect from 7/10/22 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on7/10/22... at New Delhi by



**(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250**

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi – 54.
2. The Principal, St. Giri Senior Secondary School, Pocket, 25/27, Sector-III, Rohini, Delhi-110085.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

ru
any

N/26

INSPECTION REPORT

- Name & address of the building : St. Giri Senior Secondary School, Pocket, 25/27, Sector-III, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (02 Blocks, Ground & Ground + 03 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2018/1757 dated 27.07.2018.
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 21.09.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Sanyogita Giri (Principal)
9. Year of Construction : 2003 & 2017
10. Applicant's letter No. : Online e-mail dated 20.09.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.40m	MR(Old case)
	• Basements			
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	1.5m	1.5m	MR
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	15nos.	20nos.	MR
	• Types	ABC/CO2	ABC-20	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

N/27

	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	100mm	NA
	• Number of hydrants per floor	NA	02	NA
	• Hose Box	NA	02	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

Special
Protect
Accordi
four

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 610 dated 11.08.2021, the FSC issued vide letter no. F.6/DFS/MS/2018/1757 dated 27.07.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

[Signature]
21/9/22

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

~~DO (NW)~~

[Signature]
22/09/2022

~~Dy C/O (W2)~~ What about two rooms at terrace.

[Signature]
27/9/22

~~ADO Rohini~~

May kindly peruse the photographs at C-53 to C-55, the rooms are permanently sealed by the applicant.

~~Dy C/O (W2)~~

[Signature]
30/9/22

[Signature]
27/9/22

~~ADO Rohini~~

FI letter is put up for kind perusal and signature file.

~~Dy C/O (W2)~~

[Signature]
27/9/22