

Dated: 03/10/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Metro View Guest House located at 17A/3, WEA, Karol Bagh, New Delhi- 110005**, was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/GH/2019/SZ/1582 dated 07.08.2019, for basement as storage, ground floor as reception & office, first, second and third floor each having 08 guest rooms respectively (total 24 guest rooms only). The guest house was re-inspected by the officer concerned of this department on 26.09.2022 in presence of Sh. Suresh Kumar, General manager of the guest house and found that the guest house management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) **for first, second & third floor each having 08 guest rooms respectively (total 24 guest rooms only)**, with effect from 03/10/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 03/10/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Application ID No. 2022091317515 dated 15.09.2022

Following Fire Safety Directives must be adhered to: -

1. No occupancy used above third floor and basement used for storage purpose only shall be strictly adhered by Owner/Occupier.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Metro View guest house, 17A/3, WEA, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Building Composition : Said guest house building comprised of basement, ground plus three upper floors, using basement as storage, ground floor as reception & office, 1st, 2nd and 3rd floor each having 08 guest rooms respectively (total 24 guest rooms only)
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/GH/SZ/2019/2107 dated 04.11.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 26.09.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Divisional Officer (SRD.)
9. Name and designation of officers from the building side : Sh. Suresh Kumar, manager
9. Year of Construction : 2009
10. Applicant's letter No. : Online Application Id 2022091317515 dated 15.09.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 04.11.2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	N/A	Directly accessible	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	02	02	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts	1.28 mts	MR being old case
	• Basements	1.25 mts	1.22 & 0.85 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.25 mts	1.52 to 3.0 mts	MR
	h. Door Size	1.0 mt.	0.86 cms	MR being old case
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan Provided	MR
	• Upper floors	12 a/c per hour	Exhaust fan Provided	MR
5	Fire Extinguishers			
	• Total numbers	12	Provided	MR
	• Types	CO ₂ , ABC, WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

N-15
P/19

6	First-Aid Hose Reels.	01	Provided	MR
	• Total numbers on each floor	30 m	Provided	MR
	• Length of hose reel hose	5 mm	Provided	MR
	• Nozzle diameter			
7	Automatic fire detection and alarming system.	Carbon Monoxide	Provided	MR
	• Type of detectors	Required	Provided near reception	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			Basement is less than 200 m ²
	• Basement	N/A	Provided	
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM × 2	MR
	➤ Head of the pump	40 mts	40 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 Its	10,000 Its	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR

17
18
Star
R

	<ul style="list-style-type: none"> Fireman's Grounding Switch Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Required	Provided	MR
	Total Area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F.6/DFS/MS/GH/SZ/2019/2107 dated 04.11.2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

DFA is put up for approval & signature please.

D.O. (SW) *[Signature]* 26/9/22 F.T.

Dy CRO (SZ) *[Signature]*

A.D.O. (SRD) AT. Letter is put up for sign please

Dy CRO (SZ) *[Signature]* 29/9

M.S. Cell *[Signature]* uploaded 7/10/22

[Signature] 25/9/22
 Signature of the Inspecting Officer
 Name P.V. Rathee
 Asstt. Div. Officer (SRD)