



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

cmf

No. F6/DFS/MS/School/WZ/2022/ 1116

Dated: 10/10/22

FIRE SAFETY CERTIFICATE

Certified that **Blooming Buds Educational & Welfare society**, NS-4, Block A, Pocket D, Shalimar Bagh, New Delhi comprised of basement, stilt, ground plus two upper floors owned/occupied by Blooming Buds Educational & Welfare society, was inspected by the officer concerned of this department on 28.09.2022 in the presence of Sh. Manish Gupta (Manager) and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Rule-36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and that the building/premises is fit for occupancy class "Educational" with effect from 10/10/22 for a period of three years, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules- 2010, printed overleaf.

Issued on 10/10/22 at New Delhi by.


(Anil Garg)
Director

Copy to: -

1. Shri Sidharth Jindal, General Secretary, Blooming Buds Educational & Welfare society, NS-4, Block A, Pocket D, Shalimar Bagh, New Delhi
2. The Executive Engineer (Building) HQs, 9th Floor, civic Centre, Minto Road, New Delhi- 2.
3. The Directorate of Education, Old Secretariat, Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement floor shall be used as per building bye-laws.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Blooming Buds Educational & Welfare society, NS-4, Block A, Pocket D, Shalimar Bagh, New Delhi
1. Type of Occupancy : Educational
2. Type of Case : New Case
3. Details of previous NOC : N/A
4. Fire Safety directives letter No : F6/DFS/MS/BP/2019/213 dated 06.06.2019
5. Date of inspection : 28.09.2022
6. Name of the Inspecting Officers : M.K.Chattopadhyay, D.O (West)
7. Name and designation of officers from the building side : Sh. Manish Gupta (Manager)
9. Year of Construction : 2022
10. Applicant's letter No. : E-mail dated 07-09-2022

The said School Building is comprised of basement, stilt, ground plus two upper floors

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width 	12 mts	Provided	MR
	<ul style="list-style-type: none"> • Gate width 	4.5 mts	Provided	MR
	<ul style="list-style-type: none"> • Width of internal road 	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors 	02 Nos	Provided	MR
	<ul style="list-style-type: none"> • Basements 	02 Nos	Provided	MR
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors 	1.5 mts each	Provided	MR
	<ul style="list-style-type: none"> • Basements 	1.5 mts each	Provided	MR
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 Nos	Provided	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.20 mts	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Openable window	MR
5	Fire Extinguishers			

J

116

	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 nos. ABC, CO ₂ type ISI marked	Provided	MR
6	First-Aid Hose Reels.		Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 No. 30 m 5 mm	Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system		Provided	MR
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA		N/A	N/A
9	Public Address System.		N/A	N/A
10	Automatic Sprinkler System		N/A	N/A
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants		N/A	N/A
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	Provided	N/A
		N/A	one	N/A
		N/A	one	N/A
12	Yard Hydrants.		N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump 	---	-----	-----
		2280 LPM	Provided	MR
		50 mts.	Provided	MR
		01 Nos.	Provided	MR
		1 x 180 LPM	Provided	MR
		50 mts.	Provided	MR
		2280 LPM	Provided	MR
		50 mts.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		----	Provided	MR
		900 LPM	Provided	MR

u/r

	➤ Head of the pump	50 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14 Captive Water Storage for fire fighting				
	• Underground tank capacity	2,00,000 lts.	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16 Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18 Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19 Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguishers Provided	MR

The fire protection systems provided in the building were test checked at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DFA is put up for approval & signature please

S.D. WEST/11/10/20
 DATED... 29/9/2022

(Signature)
 29/9/2022

(Signature)
 28/9/22
 Signature of the Inspecting Officer
 (M.K. CHATTOPADHYAY)
 Divisional Officer (West)

CF/O *(Signature)*
 30/9/2022
 Director *(Signature)*
 30/9/22

DO/wav