

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 1117

Dated: 10/10/2022

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya (Co-ed) Senior Secondary Vidyalaya Qutab Mehrauli New Delhi 110030 (ID- 1923004) comprised of Ground floor only owned/occupied by Directorate of Education Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/1976 Dated 16/10/2019. The said premise was re-inspected by officer concerned of this department on 23/09/2022 in presence of Mr. Amit Pandya (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and the building is fit for occupancy class "**Educational Building Group – B**" with effect from 10/10/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 10/10/2022 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to :-

1. The Principal, Sarvodaya (Co-ed) Senior Secondary Vidyalaya Qutab Mehrauli New Delhi 110030 (ID- 1923004)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/13



INSPECTION REPORT				
1	Name & Address of the Building	Sarvodaya (Co-ed) Senior Secondary Vidyalaya Qutab Mehrauli New Delhi 110030 (ID- 1923004)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1976 Dated 16/10/2019		
6	Fire Safety Directives Letter No	DOE circular dated 01/03/2011		
7	Date of Inspection	23/09/2022		
8	Name of the Inspecting Officers	Sh Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr Amit Pandya (Principal)		
10	Year of construction	1956		
11	Applicant letter No	S (co-ed) SSV/QM/2022-23/177 dated 16/09/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	06 mtr	MR
	• Gate width	NA	04 mtr	NA
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floor	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	01 m	Provided	M/R
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI mark	20 No's	MR
	• Types		ABC-10 & CO2 -10	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor	-NA-	-NA-	-NA-
	• Length of hose-reel hose	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

N/14



	<ul style="list-style-type: none"> • Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Hooster's location 	-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Hose box 	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Hose box 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➢ Discharge of main pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Head of main pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Number of main pumps 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Jockey Pump output 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Jockey Pump head 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Standby Pump output 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Standby Pump head 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Auto Starting/Manual Stopping 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Terrace Level 			
	<ul style="list-style-type: none"> ➢ Discharge of pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Head of pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Power supply 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Auto starting of pump 	-NA-	-NA-	-NA-
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Draw-off connection 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Fire Service Inlet 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➢ Access to tank 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Overhead tank capacity 	-NA-	-NA-	-NA-
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Pressurization of lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Communication in lift car 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Fireman's switch 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Lift signage 	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	NA	-NA-
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector system panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Flow switch panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • PA system panel 	-NA-	-NA-	-NA-

N/15



	<ul style="list-style-type: none"> Battery backup Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.		-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2019/SZ/1976 Dated 16/10/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh Rajesh Kumar
29/10/22

Signature of the Inspecting Officer
Name: Sh Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

F.T

Sh

ADO/BI/P

As approved, f.t. your signature pl

letter for put up for

Sh
4/10/2022

Dy CFO/SZ

Sh

M.S. cell