



461

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F 6/DFS/MS/2022/SZ/GH/462

Dated: 10/10/2022

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Young Women's Association (Regd.)** Working, Women Hostel No-II, Avenue- 21, Saket, New Delhi 110017 Comprised of 03 Building Blocks-A Block-Basement, Ground + 03 upper floors, B & C Block-Ground + 03 upper floors owned/occupied by M/s Young Women's Association (Regd.) was issued FSC by this department vide letter no F 6/DFS/MS/GH/2019/SZ/1834 dated 23/09/2019. The premise was re-inspected by officer concerned of this department on 23/09/2022 in the presence of Ms. Tanu Sharma (warden) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Residential, Group-A**" (Lodging & Rooming House) with effect from 10/10/2022 for period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 10/10/2022 at New Delhi by

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Addl. Commissioner of Police, Lic./Branch, 1<sup>st</sup> Floor, PS Defence Colony, New Delhi 110049. Ref MHA Portal ID 2022091617691 dated 16/09/2022)

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

10/10/22

N/22

### INSPECTION REPORT

1	Name & Address of the Building	M/s Young Women's Association (Regd) Working, Women Hostel No-II, Avenue- 21, Saket, New Delhi 17		
2	Type of Occupancy	Residential, "Group-A" (Guest House)		
3	Building Comprised of	Three Blocks-A Block-Basement, Ground + 03 upper floors, B & C Block-Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F 6/DFS/MS/GH/2019/SZ/1834 dated 23-09-2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23-09-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms Tanu Sharma (warden)		
10	Year of construction	1979		
11	Applicant letter No	MHA Portal ID 2022091617691 dated 16/09/2022		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	Required	Provided	MR
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	02 Nos	A Block- 02 Nos B & C Block- 01 Nos	MR
	➤ Basement floor	02 Nos	04 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25m	A-Block- 1.26m & 1.33m, B-Block- 1.33m & C-Block-1.32m	MR
	➤ Basement floor	1.25 m	1.22m, 1.20m, 1.17m & 1.11m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01 each Bk	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	1m provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers		33 Nos	MR
	• Types	ISI marked	ABC, Co2 & W Co2	MR
	• ISI Marking		Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor		01 each floor	MR
	• Length of hose-reel hose	Hose-reels	30m	MR
	• Nozzle Diameter		5mm	MR

N/23



7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box	-NA-	-NA-	-NA-
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose box	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump output	-NA-	-NA-	-NA-
	➤ Jockey Pump head	-NA-	-NA-	-NA-
	➤ Standby Pump output	-NA-	-NA-	-NA-
	➤ Standby Pump head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump house access	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump	450 & 180 LPM	450 & 180 LPM	MR
	➤ Head of pump	40m	40m each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire Service Inlet	Required	Provided	MR
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead tank capacity	10,000 Ltr	10,000 Ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft	-NA-	-NA-	-NA-
	• Pressurization of lift lobby	-NA-	-NA-	-NA-
	• Communication in lift car	-NA-	-NA-	-NA-
	• Fireman's switch	-NA-	-NA-	-NA-
	• Lift signage	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided (DG Set)	MR
18	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	<b>Fire Control Room.</b>			

May



• Detector system panel	-NA-	-NA-	-NA-
• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-
<b>20 Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F 6/DFS/MS/GH/2019/SZ/1834 dated 23/09/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

Sh  
29/9/22

Signature of the Inspecting Officer  
Name Sh Rajesh Kumar  
Design ADO (BCP)

Dy. CFO (SZ)

F.T.  
Sh

ADO (BIP)

As approved, F.T. letter is put up for your signature pl

Idg  
7/10/22

Dy. CFO (SZ)

Sh

M-S. Cell