

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2022/282

Dated: 06/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Pinjore Restaurant** running at Ground Floor of a building comprised of basement, ground plus three upper floors at Plot No. 1/4, Ground Floor, East Patel Nagar, New Delhi-110008, was granted NOC vide letter No. F.6/DFS/MS/EH/SZ/2019/2225 dated 27.11.2019. The restaurant was re-inspected by the officer concerned of this department on 28.09.2022 in presence of Sh. Harish Channa (Owner/Occupier) and found that the owners have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly **(Restaurant) (running at ground floor only)** with effect from 06/10/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 06/10/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Online application ID 2022092017931 dated 21.09.2022

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

N-12

INSPECTION REPORT

1. Name & address of the building : M/s Pinjore Restaurant, 1/4, Ground Floor, East Patel Nagar, New Delhi.
2. Type of Occupancy : Assembly (Restaurant)
3. Building Composition : said restaurant is running at ground floor of a building comprised of basement, ground plus three upper floors.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/EH/SZ/2019/2225 dated 27.11.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 28.09.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Divisional Officer (SRD)
9. Name and designation of officers from the building side : Sh. Harish Channa (Owner/Occupier)
9. Year of Construction : Before 2010
10. Applicant's letter No. : Online application Id 2022092017931 dated 21.09.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	Located at GF	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	--	-----	---
	g. Width of Corridor	2.0 mts	Opening at Hall	N/A
	h. Door Size	2.0 mts.	2.44, 1.51 & 1.10 mts	MR. being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements (other's property)	30 a/c per hour	N/A	N/A
	• Upper floors(Restaurant-GF)	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	• Total numbers	08	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N-14

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided (62 KVA)	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F.6/DFS/MS/EH/SZ/2019/2225 dated 27.11.2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

DFA is put up for approval & signature please.

Handwritten signature and date: 29/10/22

Signature of the Inspecting Officer
P.V. Rathee
Asstt. Div. Officer (SRD)

D.O. (SW)

Handwritten signature and date: 29/10/22
F.T.

Dy. S.O. (SZ)

Handwritten signature and date: 30/10/22

A.D.O. (RD)

F.T. Letter is put up for sign. please

Dy. C.F.O. (SZ)

Handwritten signature

Handwritten signature and date: 30/10/22

m.g. all

*isc uplaodetel
6/10/2022*