

C-15

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2022/ 1128

Dated: 10/10/2022

FIRE SAFETY CERTIFICATE

Certified that the building Saraswati Model School Located at Sector – 10, Dwarka, New Delhi comprised of Ground + 02 Upper Floors was issued FSC vide letter No. F6/DFS/MS/School/2019/SZ/1941, dated-11/10/2019. The premises was re inspected by the officer concerned of this department on 23/09/2022 in the presence of Sh. Vikas jain (Officiating Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service 2010, and that the premises is fit for occupancy class-B "Educational" with effect from 10/10/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/10/22 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal Saraswati Model School Located at Sector – 10, Dwarka, New Delhi.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.'
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Saraswati Model School Located at Sector - 10, Dwarka, New Delhi.
2. Type of Occupancy : Educational (G + 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/School/2019/SZ/1941, dated- 11/10/2019
5. Fire Safety directives Letter No. : As per NBC 2005
6. Date of inspection : 23-09-2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Vikas jain (Officiating Principal)
9. Year of Construction : 2016
10. Applicant's letter No. : Email dated 15-09-2022

Total Area =864 sqm. Covered Area =845 sqm Class rooms = 18 No. of students = 465
--

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	60 mtrs	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m & 1.25 m	Provided	MR (Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	1.5 m	2.6 m	MR
	f. Door Size	1 m	01 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	75,000 ltr	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2019/SZ/1941, dated-11/10/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *ADO/DWT*

DO/SO *26/9/22* *F.7.*

Dy CEO (S2)

A DO/DWK

Sir ET letter is put up for sig b/c

Dy CEO/S2 *MS. cell*

20/9/22