

No.F6/DFS/MS/School/SZ/2022/ 1142

Dated: 14/10/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **DAV Public School** located at **Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25**, comprised of Basement + Ground + 02 upper floors was granted Fire Safety Certificate by this department vide letter no. - F6/DFS/MS/School/2018/SZ/2527 dated 14.11.2018. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 27.09.2022 in the presence of Dr. V.K. Barthwal (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and the building (Basement + Ground + 02 upper floors) is fit for occupancy of Group B "**Educational Building**" with effect from ...14/10/2022 renewed for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....14/10/2022 at New Delhi by



**(Sunil Chawdhary)**  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, DAV Public School located at Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per NBC/UBBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	DAV Public School, Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25.		
2	Building is comprised of	Basement + Ground + 02 upper floors		
3	Type of occupancy	Educational		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2018/SZ/2527 dated 14.11.2018		
6	Fire safety directive letter no.	F6/DFS/MS/BP/2004/1214 dated 07.06.2004		
7	Date of inspection	27.09.2022		
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)		
9	Name of the designation of officer from the building side	Dr. V.K. Barthwal (Principal)		
10	Year of construction	2004		
11	Applicant's letter no.	DAVPS/JV/11650 dated 25.08.2022		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per directive	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6 mtrs.	12 mtrs.	MR
B	Gate width	4.5 mtrs	4.5 mtrs	MR
C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	04 nos.	04 nos.	MR
b	Basement	07 nos	07 nos.	MR
B	Width of staircases			
a	Upper floor	1.5 mtrs each	1.5 mtrs each	MR
b	Basement	1.5 mtrs	1.5 mtrs each	MR
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	02 nos.	2 nos.	MR
E	Width of corridor	1.5 mtrs.	2 mtrs.	MR
F	Door size	1 mtrs.	1 mtrs.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	Required	Provided	MR
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basement	Mechanical/ Natural	Exhaust fans, natural ventilated through two open courtyards	MR
B	Upper floor	NA	NA	NA

<b>5. Fire Extinguisher:</b>				
A	Total numbers	22 nos	22 nos	MR
B	Types	CO & ABC	CO & ABC	MR
C	ISI marking	Required	Provided	MR
<b>6. First-aid-Hose Reel:</b>				
A	Total numbers of each floor	04 nos.	04 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
<b>7. Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	<b>MOEFA:</b>	Required	Provided	MR
9	<b>Public Address System:</b>	NA	Provided	MR
<b>10. Automatic Sprinkler System:</b>				
A	Basement	Required	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11. Internal Hydrants:</b>				
A	Size of riser/ <b>down-comer</b>	100 mm	100 mm	MR
B	Number of hydrants per floor	02 nos	02 nos	MR
C	Hose box	02 nos	02 nos	MR
<b>12. Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13. Pumping Arrangements:</b>				
<b>1. Ground level</b>				
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
I	Pump house access	NA	NA	NA
<b>2. Terrace Level</b>				
A	Discharge of pump	900 LPM & 180 LPM (Jockey Pump)	900 LPM & 180 LPM (Jockey Pump)	MR
B	Head of the pump	40 mtrs	40 mtrs	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

2/26


<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	50,000 Liters	50,000 Liters	MR
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	20,000 Ltrs	20,000 Liters	MR
<b>15</b>	<b>Exit Signage:</b>			
		Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>			
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			
		NA		


**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**


**Note:-** The principal has submitted an affidavit on 27.09.200 that the multipurpose hall in the basement of aforesaid school shall not be used for any purpose of assembly. The fire protection systems provided in the building were tested checked and found not functional at the time of inspection.


The shortcomings issued to the building vide letter no. F6/DFS/MS/School/SZ/2022/85 dated 25.02.2022 has been rectified by the school management.

If agreed to the note above & In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2527 dated 14.11.2018 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

  
 Signature of the Inspecting Officer  
 Name Rajesh Kumar Shukla  
 Designation ADO (M. Road)

F.A -  
  
 Dy. CFO (SZ)

A O O (M.R.)  
 F.A is put up ple  
 Dy. CFO (SZ)  


  
 04/10/22  
 M.S. cell