



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110001

No.F.6 DFS/MS/School/2022/SZ/ \\38

Dated: \2 / \0 / 2022

## FIRE SAFETY CERTIFICATE

Certified that Govt. Girls Secondary School, at Lado Sarai, New Delhi 110030 (School ID 1923051) comprised of Ground plus Three upper floors owned/occupied by Directorate of Education Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/1133 Dated 28/07/2017. The said premise was re-inspected by officer concerned of this department on 23/09/2022 in presence of Mrs. Sunita Sharma (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and the building is fit for occupancy class "Educational Building Group—B" with effect from \[ \frac{\omega}{2} \ \scale \frac{10}{2} \ \scale \frac{10}{2} \ \frac{10}{2} \ \ 2022 for a period of Three years in accordance with rule 36 unless renewed under rule 38 of Delhi Fire Service Rules 2010.

Issued on 18/10/2022 at New Delhi by

(SUNIL CHAWDHARY) DY. CHIEF FIRE OFFICER

Copy to: -

- 1. The Principal, Govt. Girls Secondary School, at Lado Sarai, New Delhi 110030.
- 2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

## Conditions for the validity of Fire Safety Certificate


- All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 2. All the staff members must know the correct method of operation of firefighting system.
- 3. This certificate cannot be treated as regularization of unauthorized construction, if any.
- 4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <a href="https://www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>
- 5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/6



2 3 4 5 6 7 8	Name & Address of the Building  Type of Occupancy Building Comprised of Type of Case	Delhi 110030 (	econdary School, Lad School ID 1923051)	o Sarai, New		
3 4 5 6 7 8	Building Comprised of	E				
4 5 6 7 8		Educational Bui	Educational Building "Group-B" (School)			
5 6 7 8	Type of Case	Ground + 03 Upper Floors				
6 7 8		Renewal				
7 8	Details of Previous NOC		nool/2017/\$7/1133 Date:	1 28/07/2017		
8	Fire Safety Directives Letter No	F6/DFS/MS/School/2017/SZ/1133 Dated 28/07/2017 BBL/NBC Part IV				
	Date of Inspection	23/09/2022				
9	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)				
	Name & Designation of Officers	Mrs. Sunita Sharma (Principal)				
	from the building side					
10	Year of construction	2015-16				
11	Applicant letter No.	BNS/NEW Clearance/21/618 dated 01/12/2021				
S. No.		Old NOC Provided at Site Remarks				
27.101	and Fire Safety U/R 33	Old NOC Trovided at one		MR/NMR		
1	Access to Building.	requirement	,			
	Road width	09 mtr	10 mtr	MR		
	Gate width	NA	06 mtr	NA		
	Width of internal road	-NA-	-NA-	-NA-		
2	Number, width, type & arrangement of ex					
	a) Number of Staircase	its.				
	> Upper floors.	02 No's	2 No's	M/R		
	Basement floor	-NA-	-NA-	-NA-		
	b) Width of Staircase	-1421				
	> Upper floor	1 50 mtr	1.80 mtr	M/R		
	Basement floor	-NA-	-NA-	-NA-		
	c) Protection of exits		1			
	> Fire check door	-NA-	-NA-	-NA-		
	Pressurization	-NA-	-NA-	-NA-		
	d) No. of continuous staircase to terrace	Required	02 Nos	MR		
	e) Width of corridor	-NA-	-NA-	-NA-		
	f) Door size	01 m	Provided	M/R		
3	Compartmentation.					
3	Fire check door.	-NA-	-NA-	-NA-		
	Sealing of electrical shafts.	-NA-	-NA-	-NA-		
	Fire rating of shaft door.	-NA-	-NA-	-NA-		
	Water curtain	-NA-	-NA-	-NA-		
	Fire dampers.	-NA-	-NA-	-NA-		
4	Smoke Management system.					
4	Basement	-NA-	-NA-	-NA-		
	Upper floors	-NA-	-NA-	-NA-		
	Fire Extinguishers.					
5	Total numbers		24 No's	MR		
	Types	ISI mark	ABC-12 & CO2 -12	MR		
	ISI Marking		Provided	MR		
	First Aid Hose Reels.					
6	Total numbers on each floor	Hose reel	02 Nos	M/R		
	Length of hose-reel hose	30 M	Provided	M/R		
		5MM	Provided	M/R		
	Nozzle Diameter  Automatic fire detection & alarming system.					
7	Automatic fire detection & alarming system	-NA-	-NA-	-NA-		
	Type of detectors     Share Report	-NA-	-NA-	-NA-		
	Location of Main Panel		-11A-			

10/7



	Location of Repeater Panel	-NA-	-NA-	-NA-
	Alternate source of power	-NA-	-NA-	-NA-
	Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			1
	Basement	-NA-	10 mm	-NA-
	Upper floors	-NA-	02 Nos	-NA-
	Sprinkler above false ceiling	-NA-	02 Nos	-NA-
11	Internal Hydrants.			1
	Size of Riser/Down-comer	-NA-	-NA-	-NA-
	Number of Hydrant per floor	-NA-	-NA-	-NA-
	Hose box.	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	Total number of hydrants.	-NA-	-NA-	-NA-
	Hose box	-NA-	-NA-	-NA-
13	Pumping arrangements.			1
	Ground Level			
	> Discharge of main pump.	-NA-	-NA-	-NA-
	Head of main pump.	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Number of main pumps.	-NA-	-NA-	-NA-
	> Jockey Pump output.	-NA-	-NA-	-NA-
	Jockey Pump head.	-NA-	-NA-	-NA-
	Standby Pump output.	-NA-	-NA-	-NA-
	> Standby Pump head	-NA-	-NA-	-NA-
	Auto Starting/Manual Stopping.	-14/4-	-147-	-NA-
	Terrace Level			
	Discharge of pump.	450 LPM	2 x 450 LPM	MR
	Head of pump.	40 m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul> <li>Underground tank capacity.</li> </ul>	-NA-	-NA-	-NA-
	> Draw-off connection.	-NA-	-NA-	-NA-
	Fire Service Inlet.	-NA-	-NA-	-NA-
	Access to tank.	-NA-	-NA-	-NA-
	Overhead tank capacity.	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.	274	NIA	NIA.
	Pressurization of lift shaft.	-NA-	-NA- -NA-	-NA-
	<ul> <li>Pressurization of lift lobby.</li> </ul>	-NA-	-NA-	-NA-
	Communication in lift car.	-NA- -NA-	-NA-	-NA-
	Fireman's switch.		-NA-	-NA-
	<ul> <li>Lift signage.</li> </ul>	-NA-		
17	Standby Power Supply	-NA-	NA	-NA-
18	Refuge Area		NI A	-NA-
	Total area	-NA-	-NA-	
	Location	-NA-	-NA-	-NA-
19.	Fire Control Room.	•		
17.	Detector system panel.	-NA-	-NA-	-NA-
	Flow switch panel.	-NA-	-NA-	-NA-
	PA system panel.	-NA-	-NA-	-NA-
	• PA system panel			-IVA-



20.	Special Fire Protection System for the Protection of special Risk, if any.		-NA-	-NA-
	<ul> <li>Building floor plan</li> </ul>	-NA-	-NA-	-NA-
	Battery backup	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1133 Dated 28/07/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name Sh. Rajesh Kumar
Design ADO (BCP)

Dy. CFO (SZ)

ET.

cetter er proby

for your synduse Pl

06/10/27

De work

 $M, \subseteq M$