

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/2022/SZ/ 458

Dated: 14 / 10 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Natya Tarangini** located at **Plot No 49 & 52, Pushp Vihar, Sector-6, Saket New Delhi-110017** comprised of Basement, Ground plus Four upper floor (The management closed & Sealed fourth Floor, an affidavit submitted) owned/occupied by Natya Tarangini was issued FSC by this department vide letter F6/DFS/MS/School/2019/SZ/1935 dated 11/10/2019. The premise was re-inspected by the officer concerned of this department on 12/10/2022 in the presence of Mr. Mukesh Upadhyay and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Group B "Education Building" For Basement, Ground plus three upper floor only**, with effect 14/10/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 14/10/22 at New Delhi by

  
**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to:-

1. Mr. Kaushalya Reddy, Natya Tarangini at Plot No 49 & 52, Pushp Vihar, Sector-6, Saket New Delhi-110017.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/19



**INSPECTION REPORT**

1	Name & Address of the Building	Natyta Tarangini at Plot No 49 & 52, Pushp Vihar, Sector 6, Saket New Delhi-110017		
2	Type of Occupancy	Education Building "Group-D"		
3	Building Comprised of	Basement, Ground + 4 upper floor (the management closed & Sealed forth Floor an Affidavit Submitted)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1935 dated 11/10/2019		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2006/600 dated 10/03/2016		
7	Date of Inspection	12/10/2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Mukesh Upadhyay		
10	Year of construction	2013		
11	Applicant letter No.	Diary no. 6661 dated 12/10/2022		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As per Old NOC Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	12 m Required -N/A-	12 m 5 m -N/A-	MR MR -N/A-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors.</li> <li>Basement floor.</li> </ul>	02 nos 02 nos	02 nos 02 nos	MR MR
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.50 mtr 1.50 mtr	1.50 m & 1.25 m 1.50 m & 2.37 m	MR(old case) MR(old case)
	<b>c) Protection of exits</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required -N/A-	Provided -N/A-	MR -N/A-
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e) Width of corridor</b>	-N/A-	-N/A-	-N/A-
	<b>f) Door size</b>	1.0 m	1.0 m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	-N/A- Required Required -N/A- Yes	-N/A- Provided Provided -N/A- Provided	-N/A- MR MR -N/A- MR
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	Exhaust fan Provided Natural ventilation	MR MR
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	Fire Extinguisher ISI marked	12Nos ABC & CO <sub>2</sub> - Provided	MR MR MR
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	Hose reel	01 at each floor	MR

M/18



17	Standby
18.	Refuge

	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>		30 m	MR
			5 mm	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Required	Smoke type	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Ground floor	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	DG Set	MR
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	Required	Every floor	MR
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
		Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-N/A-	-N/A-	-N/A-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> </ul>	Required	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	Required	01 no	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	01 no	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	Required	01 no	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	01 no	MR
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 m	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	Required	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	-N/A-	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	25,000 ltrs	25,000 ltrs	MR
15.	<b>Exit Signage.</b>			
		Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	Required	Provided	MR

2/19



17.	Standby Power Supply	Required	DG Set Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	-N/A-	-N/A-	-N/A-
	• PA system Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/2019/SZ/1935 dated 11/10/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Dy. CFO (SZ)

*[Handwritten signature]*

F.T.

*[Signature]*  
 12/10/2022  
 Signature of the Inspecting Officer  
 Name : Sh. Rajesh Kumar  
 Designation: ADO (BCP)

ADP/BCP As approved, F.T. letter is put up for your signature pl

*[Signature]*  
 14/10/2022

*[Signature]*  
 M.S. cell