

7-
10/10/2022

C/24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2022/SZ/ 1157

Dated: 18/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Don Bosco School** situated at Alaknanda, New Delhi-110019, comprised of **Ground + three upper floors** owned/occupied by **Don Bosco School** was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/SZ/1779 Dt. 17-09-2019. The premise was re-inspected by the officer concerned by this department on 10/10/2022 in the presence of Mr. Binoy (Accountant) and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group-B Educational**" with effect from 18/10/2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 18 / 10 /2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Don Bosco School situated at Alaknanda, New Delhi-110019
2. The Dy. Director of Education (South), Directorate of Education (South District), Govt. of NCT of Delhi, Sector-3, RK Puram, New Delhi-110022

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/14

7/11/2022

INSPECTION REPORT

1	Name & Address of the Building	M/s Don Bosco School located at Alaknanda, New Delhi-110019		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Two Blocks: Each of Ground + 03 Upper floors & One block of Stilt + 01 Upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2019/SZ/1779 Dt. 17-09-2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	10/10/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Binoy (Accountant)		
10	Year of construction			
11	Applicant letter No.	Email dated 12-09-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	9m	10m	MR
	• Gate width	5m	4.5m	MR (old case)
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	Two Nos	2 Nos=GF to terrace, 1 No= GF to 3 rd F, 1 No=GF to terrace & 1 No=GF to 1 st Floor (both blocks are interconnected at 1 st Floor)	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.5m	3 Nos=1.5m + 1.4m + 1.35m	MR (Old case)
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	One	2 Nos	MR
	e) Width of corridor	1.5m	1.7m	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	24 Nos ISI marked	30 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose Reels	4 upto 1 st F & 2 on above floors	MR
	• Length of hose-reel hose		30m	MR
	• Nozzle Diameter		5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A

Don Bosco School located at Alaknanda, New Delhi-110019

N/15

Sl. No.	Requirement	Required	Provided	Remarks
8	MOEFA			
9	Public Address System			MR
10	Automatic Sprinkler System	N/A	Provided	N/A
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	4 upto 1 st F & 2 on above floors	Provided	MR
	• Hose box.	4 upto 1 st F & 2 on above floors	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	2 x 450 LPM	MR
	➤ Head of pump.	40m	35m (each)	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	1,00,000 Lts	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Lts	20,000 Lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of Special Risk, if any.	N/A	N/A	N/A

M16



Don Bosco School located at Alaknanda, New Delhi-110019

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2019/SZ/1779 Dt. 17-09-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh. Rajesh Kumar
11/10/22

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

F.T.
Sh.

~~ADO~~ *Sh.*

As approved, F.T. letter is put up for your signature.

Sh.
12/10/22

Dy. CFO (SZ)

Sh.

M.S. all

MR
N/A
N/
N/
N/
N/
N/
N/
N/A
MR
MR
MR
MR
/A
/A
A
A
R