

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No.F6/DFS/MS/2022/School/ 1149

Dated: 18/10/2022

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Co-ed School** located at **5306/12, New Chandrawal, Near Apollo Pharmacy, Delhi-110007** comprised of **Ground floor only** was granted FSC by this department vide letter No.F6/DFS/MS/2019/1808 dated 19.09.2019. The premises was re-inspected by the officer concerned of this department on 27.08.2019 in presence of **Smt. Nirmal Gupta, Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from 18.10.2022 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 18.10.2022 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250
etc

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi – 110054.
2. The Principal, M.C. Primary Co-ed School located at 5306/12, New Chandrawal, Near Apollo Pharmacy, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

- Name & address of the building : M C Primary Co-ed School at 5306/12, New Chandrawal, Near Apollo Pharmacy, Delhi-110007
- 2 Type of Occupancy : Educational
- 3 Composition of building : Ground Floor only
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6 DFS MS 2019 1808 dated 19 09 2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 30 09.2022
8. Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Smt. Nirmal Gupta(Principal)
- 10 Year of Construction : 1934
11. Applicant's letter No. : Online E-mail Dated- 16.09.2022

Plot Area-6200 m2

Covered Area:5200 sq. ft

No of Class Room-08

No of Student- 145nos

| | Minimum Standards on fire prevention and fire safety U/R 33 | Director of Education Circular Requirements | Provided at site | Remarks MR/NMR |
|--------------------------------|---|---|--------------------|----------------|
| 1 | Access to building | | | MR |
| | • Road width | 5m (old case) | 5m (old case) | MR |
| | • Gate width | 3m(old case) | 3m (old case) | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | NA | NA | NA |
| | • Upper Floors | | | |
| | • Basements | | | |
| | b Width of staircases | NA | NA | NA |
| | • Upper Floors | NA | NA | NA |
| | • Basements | | | |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | 1 m | 1m | MR |
| | f. Door Size | | | |
| | 3 | Compartmentation. | NA | NA |
| • Fire check door | | NA | NA | NA |
| • Sealing of electrical shafts | | NA | NA | NA |
| • Fire Rating of shaft door | | NA | NA | NA |
| • Water Curtain | | NA | NA | NA |
| • Fire Dampers | | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 12 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural Ventilated | MR |
| 5 | Fire Extinguishers | | | |

| Captive Water Storage for fire fighting. | | | |
|--|--|----------|----------|
| | • Underground tank capacity | NA | NA |
| | ➤ Draw-off connection | NA | NA |
| | ➤ Fire service inlet | NA | NA |
| | ➤ Access to tank | NA | NA |
| | • Overhead Tank capacity | NA | NA |
| 15 | Exit Signage. | Required | Provided |
| 16 | Provision of Lifts. | | |
| | • Pressurization of Lift Shaft | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A |
| | • Communication In lift Car | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A |
| | • Lift Signage | N/A | N/A |
| 17 | Standby power supply | N/A | N/A |
| 18 | Refuge Area. | | |
| | ➤ Total Area | N/A | N/A |
| | ➤ Location | N/A | N/A |
| 19 | Fire Control Room | | |
| | • Detector System Panel | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A |
| | • PA System Panel | N/A | N/A |
| | • Batter backup | N/A | N/A |
| | • Building Floor Plans | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1808 dated 19.09.2019.

DO/NW — ON leave

DO(SW) *[Signature]*

[Signature] 3/10/22
Dy. Secy (NW)

~~Asst. Secy R-N~~

[Signature] 6/10/22

As approved, F.T. letter is put up for your signature pl.

[Signature]
Signature of the Inspecting Officer
Name: - C.L. Meena
Designation: - ADO/RN

[Signature] 10/10/2022 Cont....