

← 18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/2022/School/ NW2/1147

Dated: 18 / 10 /2022

**FIRE SAFETY CERTIFICATE**

Certified that **M.C.D School (I.D No. 1253169)** located at **Swaroop Nagar-II, Near NDPL, Transmission office, Delhi-110042** comprised of **Ground & first floor only** owned/occupied by **M.C.D School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2019/WZ/2229** dated **27.11.2019**. The premises was re-inspected by the officer concerned of this department on **01.10.2022** in presence of **Sh. Jamidar Singh (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy "**Class Group B Educational**" with effect from 18/10/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 18/10/2022 at New Delhi by

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph.-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, M.C.D School (I.D No. 1253169) located at Swaroop Nagar-II, Near NDPL, Transmission office, Delhi-110042.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1	Name & address of the building	M C D Primary Girls School, Swaroop Nagar, Delhi- 110042
2	Type of Occupancy	Educational
3	Composition of building	Ground +01 upper floor only
4	Type of Case	Renewal
5	Details of previous NOC	F6 DFS/MS 2019 W/ 2229 dated 27.11.2019
6	Fire Safety directives letter No	Nil
7	Date of inspection	01.10.2022
8	Name of the Inspecting Officers	ADO (RN)
9	Name and designation of officers from the building side	Sh Jmidar Singh (Principal)
10	Year of Construction	1991-2007
11	Applicant's letter No	Nil dated 09.09.2022 & Dairy No 5462 dated 09.09.2022

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular Requirements 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b Width of staircases			
	• Upper Floors	1.5m <del>0.9m</del>	1.75m	MR
	• Basements	NA	NA	NA
	c Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d No of continuous staircases to terrace	NA	NA	NA	
e Width of Corridor	NA	NA	NA	
f Door Size	1m	1.15m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	04nos	05nos	MR

Dr

Signature

N/15

	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>	NA	NA	NA
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 2229 dated: 27.11.2019.

DO (NW) — ON Leave

~~DO (SW)~~

*Adh*  
3/10/22

~~Dy. CEO (W2)~~

~~ADO/RN~~  
*M. S. Jaiswal*

*G. K. Sharma*

*C. L. Meena*  
Signature of the Inspecting Officer  
Name: - C.L. Meena  
Designation: - ADO/RN

As approved, F.T. letter is put up for your signature pl.

*C. L. Meena*  
7/10/2022

*C. L. Meena*

	<ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>	ABC/Co2	ABC-05	MR
6	<b>First-Aid Hose Reels.</b>	ISI Marked	Yes	MR
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	NA
		NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	N/A	NA
		NA	N/A	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>	N/A	N/A	N/A

*[Handwritten signature]*